

** 10" OR AS CLEARANCE ALLOWS

RETURN GRILLE SOUND BOOT DETAIL

1 1/2" = 1'-0" | 00D-M0301-H0D-GRIL | H | 02/20/2014



NOTE: PROVIDE RUBBER FLOOR MATS AROUND ALL ROOFTOP EQUIPMENT.

ROOFTOP UNIT CURB ASSEMBLY DETAIL

NTS | 00D-M0301-J0O-UNIT | D | 10/31/2014

UPON AN ALARM IN MALL FIRE ZONE # 3 – VICTORIA'S SECRET, THE RESPECTIVE RTU SHALL SHUT DOWN FROM SIGNAL FROM BUILDING DDC CONTROL SYSTEM AND POWER EXHAUST FAN INSIDE RTU SHALL START. DAMPERS/POWER EXHAUST TO ALLOW SMOKE TO BE BROUGHT THROUGH RETURN TO EXHAUST TO OUTSIDE. OUTSIDE AIR DAMPERS (ECONOMIZER DAMPERS) TO CLOSE.

UPON AN ALARM IN FIRE ZONE OF VICTORIA SECRET, THE RESPECTIVE RTU SHALL RECEIVE SIGNAL FROM BUILDING DDC CONTROL SYSTEM AND GO INTO 100% OUTSIDE AIR FOR PRESSURIZATION. RTU TO CONTINUE TO RUN.

REMOTE FIREMAN'S OVERRIDE 3 POSITION SWITCH IN SPACE SHALL ALLOW FOR OVERRIDE OPERATION OF RTU:

A. COMPLETE RTU SHUTDOWN
B. NORMAL OPERATION
C. POWER EXHAUST – PURGE

SMOKE EVACUATION SEQUENCE OF OPERATION

N.T.S. | - | M



DUCTED GRILLE DETAIL

3" = 1'-0" | 00D-M0301-G00-GRIL | G | 09/13/13



TOILET EXHAUST IN-LINE MOUNTING DETAIL

NTS | 00D-M0301-C00-EFAN | C | 09/13/13



SMOKE EVACUATION SCHEMATIC

N.T.S. | - | K



NOTE: FOR REMOTE DAMPER ADJUSTMENT

NOTE: COORDINATE EXACT LOCATION OF CEILING MOUNTED CONCEALED REGULATOR WITH ARCHITECT PRIOR TO INSTALLATION.

YOUNG REGULATOR REMOTE DAMPER

NTS | 00D-M0301-F00-DAMP | F | 12/11/13



NOTE: USE PLAN AS GUIDE TO FITTING TYPE.

DUCT DETAILS

NTS | 00D-M0301-B00-DUCT | B | 09/13/13



SMOKE EVACUATION DETAIL

N.T.S. | - | J



DRYWALL CEILING DIFFUSER MOUNTING FRAME DETAIL

1" = 1'-0" | 00D-M0301-E00-FRME | E | 02/18/14



NOTE: ALL DIFFUSERS ARE 4–WAY BLOW UNLESS NOTED OTHERWISE. PROVIDE OPTIONAL DIRECTIONAL BLOW, TITUS MODEL "DB" TO CONVERT DIFFUSER FROM STANDARD 4–WAY TO 1–WAY, 2–WAY OR 3–WAY BLOW AS DESIGNATED ON PLANS BY SHADED AREA.

WITH MANUAL VOLUME DAMPER

CEILING DIFFUSER MOUNTING DETAIL

NTS | 00D-M0301-A00-DIFF | A | 09/13/13

TBA
Thorson • Baker + Associates
CONSULTING ENGINEERS
3030 West Streetsboro Road (330) 659-6688 Ph.
Richfield, Ohio 44286 (330) 659-6675 Fax

Lbrands

STORE DESIGN & CONSTRUCTION

Three Limited Parkway • Columbus, Ohio 43230
Telephone: 614.415.7000 • Fax: 614.415.7349

THESE DRAWINGS AND SPECIFICATIONS ARE COPYRIGHTED AND SUBJECT TO COPYRIGHT PROTECTION AS AN "ARCHITECTURAL WORK" UNDER SEC. 102 OF THE COPYRIGHT ACT, 17 U.S.C. AS AMENDED DECEMBER 1990. THE ARCHITECTURAL WORKS PROTECTED INCLUDE THE OVERALL FORM AS WELL AS THE ARRANGEMENT AND COMPOSITION OF SPACES AND ELEMENTS IN THE DESIGN. UNDER SUCH COPYRIGHT, UNAUTHORIZED USE OF THESE DRAWINGS AND SPECIFICATIONS MUST BE ATTENDED TO LOSS: LOSS COMPENSATION OF THEIR INTENDED USE. IMAGES CREATED BY THE LOSS.

PROJECT INFORMATION:

010500587

VICTORIA'S SECRET

NORTH POINT MALL

SPACE #1050
1000 NORTH POINT CIRCLE
ALPHARETTA, GA 30022

FULL REMODEL | PACKAGE: SPRING 2015 (142Fc) PKG II
NMA GENERATION: 140332
A/E PROJECT #: 00059876

SCOPE:
DESIGN TYPE:
LSDAC PROJECT #:

REVISIONS:

	REQUIRED BY:	DATE
1	BID ADDENDUM – LANDLORD COMMENTS & WASTED UPDATES (0515s.01 & 015A)	01/02/2015

ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979-285-0712
NOTE: THESE PRINTS HAVE BEEN REDUCED BY 50 PERCENT. SCALE WILL BE 50 PERCENT OF WHAT IS NOTED ON PLANS

DATE ISSUED: 09/19/14
DESIGNED BY: MAP
DRAWN BY: TBA
CHECKED BY: JMZ

MECHANICAL DETAILS

DRAWING NUMBER:

M03.01