



- CONNECT (N) 4" SANITARY SEWER BELOW SLAB TO (E) SANITARY SEWER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 4").
 - CONNECT (N) 3/4" COLD WATER TO (E) COLD WATER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 3/4"). REMOVE EXISTING PIPING DOWNSTREAM OF CONNECTION POINT. FIELD VERIFY IT DOES NOT SERVE OTHER TENANTS PRIOR TO REMOVING.
 - P.O.C. OF (N) VENT TO (E) VENT LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 2"). REMOVE EXISTING PIPING DOWNSTREAM OF CONNECTION POINT. FIELD VERIFY IT DOES NOT SERVE OTHER TENANTS PRIOR TO REMOVING.
 - 1" CONDENSATE DRAIN ON ROOF TO ROOF DRAIN. REFER TO DETAIL 3 ON SHEET P03.01. CONDENSATE DRAIN TO BE COPPER, AND MUST BE INSTALLED FROM THE UNIT TO ROOF DRAINS WITH 4" X 4" REDWOOD BLOCKS SPACED 3'-0" ON CENTER.
 - PLUMBING CONTRACTOR TO PROVIDE WATER METER - PER LANDLORD. WATER METER MUST BE PURCHASED FROM METER TECHNOLOGY WORKS, LLC. CONTACT: 813-334-4728, OR EDWIN COOKE AT 813-205-2150. METER TO BE AMCO MODEL C700 AND TO READ IN GALLONS. VERIFY LOCATION. MOUNT 48" ABOVE FINISHED FLOOR. MAKE NECESSARY CONNECTIONS AS REQUIRED. WATER METER MUST BE TIED INTO MALL EMS THROUGH A POINT OFF THE XRAY BOX CONTROLLER. WATER METER WIRING IS REQUIRED TO BE INSTALLED BY WAYPOINT SYSTEMS AT TENANT'S EXPENSE. CONTACT: ANDREW SEGAL OR PAUL BENNETT AT 770-648-6100.
 - RAISE EXISTING PIPING AS REQUIRED TO MAINTAIN NEW CEILING HEIGHT. SEE ARCHITECTURAL DRAWINGS FOR NEW CEILING HEIGHTS. COORDINATE WORK WITH LANDLORD.
 - EXISTING PIPING TO REMAIN.
 - PROVIDE DRIP PAN PER CODE FOR EXISTING SPRINKLER PIPE OVERTOP OF NEW ELECTRICAL EQUIPMENT AS REQUIRED.
- LANDLORD NOTE:**

 - ALL FIRE ALARM SYSTEM WORK BY MALLS REQUIRED FIRE ALARM CONTRACTOR. POWER SUPPLY AND ALL HORNS & STROBES BY APEX FIRE. NO PULL STATIONS, FLOW SWITCHES, OR BELLS AS INDICATED ON PLANS.
 - EMPLOY LANDLORD'S APPROVED CONTRACTOR FOR ALL SPRINKLER WORK.
 - PVC PIPE LOCATED ABOVE SLAB ON GRADE SHALL BE FIRE WRAPPED OR ENCASED IN 5/8" GYPBOARD.
- GC SHALL PROVIDE WRITTEN REPORT TO LSD&C PM ON CONDITION OF EXISTING SEWER TIE-IN REGARDING SLOPE AND FLOW.

 - SCOPE WITH CAMERA PRIOR TO CONNECTION
 - DO NOT CONNECT WITHOUT LSD&C PM AUTHORIZATION IF SPECS NOT MET
- NOTE:**

REFER TO SPECIFICATION BOOKLET FOR ADDITIONAL INFORMATION.

PLUMBING AND FIRE SPRINKLER HEAD PLAN KEYNOTES	NTS	D
	-	09/02/11

PLUMBING AND FIRE SPRINKLER HEAD PLAN

"VERIFY ALL FIELD CONDITIONS PRIOR TO BID"

1/4" = 1'-0"

TBA
Thorson • Baker + Associates
CONSULTING ENGINEERS
3030 West Streetsboro Road
Richfield, Ohio 44286
(330) 656-6688 PH
(330) 656-6675 FAX

Lbrands
STORE DESIGN & CONSTRUCTION
Three Limited Parkway • Columbus, Ohio 43230
Telephone: 614.415.7000 • Fax: 614.415.7349

PROJECT INFORMATION:

VICTORIA'S SECRET
NORTH POINT MALL
SPACE #1050
1000 NORTH POINT CIRCLE
ALPHARETTA, GA 30022

SCOPE: REMODEL
DESIGN TYPE: N/A
LSD&C PROJECT #: 00059876

REVISIONS:

REVISED BY:	DATE:
BY ADDENDUM - LANDLORD COMMENTS	01/02/2015
BY MASTER UPDATES (15156.01 & 0156A)	

ELITE CONSTRUCTION GROUP
LANSING, MI 48201
PHONE: 979-285-0712
NOTE: THESE PRINTS HAVE BEEN REDUCED BY 50 PERCENT. SCALE WILL BE 50 PERCENT OF WHAT IS NOTED ON PLANS.

DATE ISSUED: 09/19/14
DESIGNED BY: MAR
DRAWN BY: TBA
CHECKED BY: JMZ

PLUMBING AND FIRE SPRINKLER HEAD PLAN

DRAWING NUMBER: P02.01

010500587

PKG II
FULL REMODEL
N/A
GENERATION: SPRING 2015 (142Fo)
A/E PROJECT #: 00059876