1. LIGHTING SHALL BE CIRCUITED EXACTLY AS SHOWN ON PLANS. CIRCUITING SHALL BE "THRU-WIRING" WHERE AND WHENEVER POSSIBLE. MULTIPLE CONNECTIONS TO A SINGLE LIGHT FIXTURE FOR VOLTAGE DROP CONDITIONS OR AS A RESULT OF A FIELD CONDITION ARE ACCEPTABLE. LIGHT FIXTURES SHALL BE MANUFACTURED TO ACCOMMODATE "THRU-WIRING". ANY RELATED COSTS FOR MULTIPLE CONNECTIONS SHOULD BE INCLUDED IN BID.

2. ELECTRICAL CONTRACTOR'S BID SHALL INCLUDE THE INSTALLATION OF ALL LIGHT FIXTURES AND ASSOCIATED LAMPS FURNISHED BY LSD&C. ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ENSURING THE ADJUSTABILITY OF ALL DIRECTIONAL FIXTURES AFTER INSTALLATION AND AIM THEM PER QC DIRECTION. LIGHT FIXTURE SPECIFICATIONS MAY VARY. IF THIS IS THE CASE, CONTRACTOR IS TO CALL LSD&C PURCHASING AGENT WHO WILL THEN CALL THE DISTRIBUTOR FOR EXACT SPECIFICATION OF LIGHTING FIXTURES. IF THE CEILING SYSTEMS ARE FIRE RATED, ELECTRICAL CONTRACTOR IS TO CLOSELY COORDINATE FIXTURE REQUIREMENTS WITH LSD&C.

3. EMERGENCY AND EXIT LIGHTS SHALL BE INSTALLED AND CIRCUITED PER LOCAL AND LATEST NATIONAL ELECTRICAL CODES. ALL EMERGENCY AND EXIT FIXTURES SHALL BE DUAL VOLTAGE WITH BATTERY BACK UP (120/277 VOLT INPUT). INSTALL A CENTRAL BATTERY SYSTEM WHERE THE USE OF INDIVIDUAL BATTERY UNITS ARE PROHIBITED BY LOCAL CODES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSD&C PROJECT MANAGER FOR DIRECTION.

4. ALL LIGHTING CIRCUITS UP TO 100'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS FROM 100'-1" TO 150'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS 150'-01" UP TO 250'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM. CIRCUITS ABOVE 251'-0" SHALL UTILIZE #6 CONDUCTORS MINIMUM.

5. ELECTRICAL CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS AS REQUIRED FOR A FULLY COMPLETE AND OPERABLE SYSTEM.

6. EXIT/EMERGENCY LIGHTS AT STOREFRONT ARE TO BE CEILING MOUNTED AND CENTERED OVER OPENING. EXIT/EMERGENCY LIGHTS AT DOOR TO NON-SALES SHALL BE CEILING MOUNTED AND CENTERED ABOVE DOOR. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT THE LSD&C PROJECT MANAGER FOR DIRECTION.

7. IT WILL BE THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO UNLOAD INVENTORY AND STORE LIGHTING PACKAGE. THE ELECTRICAL CONTRACTOR WILL ALSO SHIP ANY EXCESS MATERIALS BACK TO THE ELECTRICAL PACKAGE DISTRIBUTOR.

8. ELECTRICAL CONTRACTOR SHALL REFER BACK TO ARCHITECTURAL SHEETS FOR MOUNTING HEIGHTS OF ALL WALL MOUNTED EMERGENCY EGRESS AND EXIT FIXTURES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSD&C PROJECT MANAGER FOR DIRECTION.

9. REFER TO ARCHITECTURAL DRAWINGS FOR COORDINATION AND EXACT LOCATION OF EXIT SIGNS, EMERGENCY LIGHTING FIXTURES, SPEAKERS, DIFFUSERS, AND OTHER ARCHITECTURAL ELEMENTS.

10. THE ELECTRICAL CONTRACTOR MUST INCLUDE IN THE BID TWO (2) HOURS OF START-UP TIME FOR THE LIGHTING CONTROL SYSTEM. THE ELECTRICAL CONTRACTOR WILL BE REQUIRED TO REPAIR OR REPLACE COMPONENTS FOUND TO BE DEFECTIVE. THE ELECTRICAL CONTRACTOR MUST COORDINATE LIGHTING CONTROL START-UP WITH BAS SUPPLIER REPRESENTATIVE. FAILURE TO DO SO MAY REQUIRE THE ELECTRICAL CONTRACTOR TO RETURN TO THE JOB SITE TO PERFORM START-UP AT A FUTURE DATE AT THE ELECTRICAL CONTRACTOR'S OWN EXPENSE.

11. ALL APPURTENANCES PROVIDED WITH LIGHT FIXTURES, OR TRACK, ETC. POLARITY REVERSING ENDS, SHALL BE INSTALLED PER MANUFACTURER'S INSTRUCTIONS.

LIGHTING PLAN CONSTRUCTION NOTES

NTS

05N-E0401-N00-NOTE

N
08/15/11

SYMBOL	DESCRIPTION	MANUFACTURER & MODEL NUMBER	LAMP	WATTAGE
A5	7" DIAMETER RECESSED COMPACT FLUORESCENT DOWNLIGHT, CLEAR CONE, MATTE FINISH, ELECTRONIC BALLAST, SELF FLANGED REFLECTOR ENERGY REDUCTION.	HALO-PORTFOLIO: C7032-1E-7001-H LIGHTOLIER-CALCULITE: 8022CCDP, 7132BU LITHUNIA-GOTHAM: AFV26TRFARLDWVOLT JUNO: CV6-126/32T-600C-SE	26 WATT, T4, 4PIN GX24Q-3 BASE, TRIPLE COMPACT FLUORESCENT, 3000K, 82CRI, 16,000 HRS.	32 WATTS
B5	3" RECESSED 15 DEGREE 3000K LED MR16 ADJUSTABLE DOWNLIGHT, WHITE TRIM, MAGNETIC TRANSFORMER, 15W MAX LABEL	CONTECH: LVR316; CTR325-P-15W	7 WATT DIMMABLE LED MR16 GU5.3 BASE 3000K 15 DEGREE BEAM 25,000 HR	7 WATTS
B6	3" RECESSED 15 DEGREE 3000K LED MR16 DOWNLIGHT, MATTE WHITE PIN HOLE TRIM, BLACK REFLECTOR, MAGNETIC TRANSFORMER, 15W MAX LABEL	CONTECH: LVR316/ CTR305-BLK-MW-15W	7 WATT DIMMABLE LED MR16 GU5.3 BASE 3000K 15 DEGREE BEAM 25,000 HR	7 WATTS
BG	9 MINI-DOWNLIGHT LED RECESSED FIXTURES WITH WHITE FINISH. (1) PRE-WIRED 700mA LED DRIVER WITH 60" CORD.	AMERLUX: VSMPL-4-LED-MW-17/40-2700(PUCK LIGHTS) AMERLUX: VSMPL-PS-50-12V-120	3.0 W LED	27 WATTS
BP	3" DIAMETER RECESSED ADJUSTABLE MR16 DOWNLIGHT, CLEAR CONE, WHITE TRIM, INTEGRAL ELECTRONIC BALLAST.	RSA: MLV3055: C-800	35-37 WATT HIR OR 50 WATT HALOGEN, MR16, 2 PIN GX 5.3 BASE, QUARTZ HALOGEN, NARROW FLOOD 24-30, 3500-6000 HRS.	55 WATTS
BT	3" DIAMETER RECESSED ADJUSTABLE MR16 ACCENT LIGHT, CONICAL DROP HINGE LAMP, MATTE BLACK FINISH, 358° ROTATION, 85° ADJUSTABILITY, INTEGRAL ELECTRONIC TRANSFORMER, SECURE HOUSING TO STRUCTURE	RSA: MLV3086, C500/EL/MBA-35 CON-TECH: LVR316, CTR325-B-35	35 watt HIR, MR16, 2 Pin GU 5.3 Base, Quartz Halogen, Flood 36°, 5000 Hrs.	35 WATTS
C2	4" DIAMETER RECESSED HALOGEN MR16 LENSED WALLWASHER, CLEAR CONE, MATTE FINISH, SELF FLANGED REFLECTOR.	LITHUNIA-GOTHAM: DLV WSH MR16 4 AC LD 120	35-37 WATT HIR OR 50 WATT HALOGEN, MR16, 2 PIN GX 5.3 BASE, QUARTZ HALOGEN, NARROW FLOOD 24-30, 3500-6000 HRS.	55 WATTS
F2	2' BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION	MERCURY: MM-117-OCT-C-ELB-120V	17 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000 HRS.	17 WATTS
F3	3' BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION	MERCURY: MM-125-OCT-C-ELB-120V	25WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82CRI, 20,000 HRS.	25 WATTS
F4	4' BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION	MERCURY: MM-132-OCT-C-ELB-120V	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82 CRI, 20,000 HRS.	32 WATTS
F9	4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, WITH EMERGENCY PACK WITH WIRE GUARD.	MERCURY: MM-132-OCT-C-ELB-120V-EMPK - WG=MM-132, CHAIN/3FT	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82 CRI, 20,000 HRS.	32 WATTS
FK	4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION WIRE GUARD	MERCURY: MM-132-OCT-C-ELB-120V, WG-MM-132, CHAIN/3FT	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82 CRI, 20,000 HRS.	32 WATTS
H6	3' LINEAR LOW PROFILE T8 FLUORESCENT INTEGRAL BALLAST. WHITE FINISH	BARTCO: BFL255-25-120	25WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82CRI, 20,000 HRS.	25 WATTS
H7	4' LINEAR LOW PROFILE T8 FLUORESCENT INTEGRAL BALLAST, WHITE FINISH	BARTCO: BFL255-32-120	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82 CRI, 20,000 HRS.	32 WATTS
H9	6' LINEAR LOW PROFILE T8 FLUORESCENT INTEGRAL BALLAST, WHITE FINISH	BARTCO: BFL255-2525-120	25WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82CRI, 20,000 HRS.	50 WATTS
KA	PAR30 FRONT LOADING GIMBAL RING TRACK HEAD, MATTE BLACK FINISH	CONTECH: CTL8116B/LA2050B	50 WATT, PAR30	50 WATTS
KL	MR16 GIMBAL RING TRACK HEAD, INTEGRAL ELECTRONIC TRANSFORMER, MATTE BLACK FINISH	CONTECH: CTL2830B	35 WATT, MR16, HALOGEN	35 WATTS
M1	2" DIAMETER MR16 GIMBAL RING TRACK HEAD ON RECESSED MONO-POINT WITH REMOTE ELECTRONIC TRANSFORMER, WHITE FINISH	JUNO: TL166WH, TL543WH HALO: LV30AP, LV20RP CON-TECH: CTL8116P, CTR18P, LVR16-TH	35-37 WATT HIR OR 50 WATT HALOGEN, MR16, 2 PIN GX 5.3 BASE, QUARTZ HALOGEN, NARROW FLOOD 24-30, 3500-6000 HRS.	55 WATTS
N1	1' X 4' SURFACE MOUNTED SINGLE LAMP FLUORESCENT TROFFER, PRISMATIC ACRYLIC LENS, ELECTRONIC BALLAST	MERCURY: M30-132-QCT-9A-ELB-120V	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 82 CRI, 20,000 HRS.	32 WATTS
N2	RECESSED HIGH PERFORMANCE 1X4 VOLUMETRIC TROFFER FOR USE IN A GYP CEILING	PINNACLE: CJ14A-1T8-FL-120-1C-W	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 85 CRI, 30,000 HRS.	32 WATTS
N2E	RECESSED HIGH PERFORMANCE 1X4 VOLUMETRIC TROFFER WITH EMERGENCY BATTERY BACKUP FOR USE IN A GYP CEILING	PINNACLE: CJ14A-1T8-FL-120-1B-W	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 85 CRI, 30,000 HRS.	32 WATTS
N3	2-LAMP T8 INDIRECT/DIRECT LINEAR 48" FIELD ADJUSTABLE DROP PENDANT FOR USE IN A 15/16" 2X2 TILE SUSPENSION CEILING. AFF 8'	COOPER CORELIGHT: AB-W-0-2-T8-1-C-120-A-C-48"(ADJ)-T1 =*RUN LENGTH*	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 85 CRI, 30,000 HRS.	64 WATTS
N3E	2-LAMP T8 INDIRECT/DIRECT LINEAR 48" FIELD ADJUSTABLE DROP PENDANT WITH EMERGENCY BATTERY BACKUP FOR USE IN A 15/16" 2X2 TILE SUSPENSION CEILING. AFF 8'	COPPER CORELIGHT: AB-W-0-2-T8-1-B-120-A-C-48"(ADJ)-T1= *RUN LENGTH*	32 WATT, T8, MEDIUM BI-PIN BASE, LINEAR FLUORESCENT, 3000K, 85 CRI, 30,000 HRS.	64 WATTS
NA	WALL MOUNTED "LOVE PINK" 20.25" X 94.25" WHITE SKELETON NEON SIGN, 4500K W. PLENUM RATED TRANSFORMER BOX, HARDWIRE CONNECTION	OSM VENDOR	NEON	756 WATTS
NR	WALL MOUNTED"PINK" 21"X68.5" BULB CHANNEL INDIVIDUAL LETTERS W/ POLISHED BRASS RETURNS (74) FROSTED LED LAMPS IN FIXTURE. INDIVIDUAL DUPLEX OUTLER PER LETTER	OSM VENDOR	G16.5 MEDIUM BASE LED 2900K, 2 WATTS 12,000 HRS	148 WATTS
PK	35" LINEAR T5 WHITE FINISH UNDERSHELF TASK LIGHT, STANDARD UL/CUL CODES, NORMAL BALLAST FACTOR, WITH NO DIMMER AND ATTACHEMENT BRACKET FOR C-STYLE STORAGE. 3500K LAMPS PROVIDED / MAINTAIN WITH 3000K STANDARD T5 LAMPS.	BY OSM PROVIDER HERMAN MILLER: G611-4-42-E-N-0-91	21 WATT, T5, MINIATURE BI-PIN BASE, PROGRAMMED START LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000 HRS.	21 WATTS
PM	TWO LIGHT DECORATIVE FLUSH MOUNTED PENDANT W/ ANTIQUE NICKEL FINISH SCALLOPED WHITE FABRIC SHADE	ROBERT ABBEY AXIS 16" WIDE ANTIQUE NICKEL CEILING LIGHT: ITEM # D2139	11 WATT MED. BASE LED, 800LUMENS, 25,000HRS, 81 CRI, 2700K	22 WATTS
R1	BEAUTY Z FIXTURE (6) 36" T5 WARM WHITE FLOURESCENTS WITH PLEXIGLASS COVER AND INTREGAL BALLAST	WAM: HERA ES34	21 WATT, T5, MINIATURE BI-PIN BASE, PROGRAMMED START LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000 HRS.	152 WATTS
RA2	FRAGRANCE TABLE SHORT: (2) JESCO DB-CV CONNECTION BLOCK (2) FAWOO AC ADAPTORS 12V (2) FAWOO 11 5/8" X 17 5/8" 5300K LEDPANEL (1) FAWOO 2 7/16" X 11 3/8" 5300K LEDPANEL (1) 3 1/4" X 25 1/4" 5300K LEDPANEL (1) FAWOO 26" X 73" 5300K LEDPANEL	JESCO: DB-CV-DC/AMPS6 FAWOO:12V5A/MCW480B-15 FAWOO: 11 5/8" X 17 5/8" LED PANEL FAWOO: 2 7/16" X 11 3/8" LED PANEL FAWOO: 3 1/4" X 25 1/4" LED PANEL FAWOO: 26" X 73" LED PANEL	LED5300K	288 WATTS
S2	BEAUTY TRANSITION FOCAL SHALLOW FAWOO LED STRIPLIGHTS: (2) 1000MM, (2)1420MM, (8) 64MM. (1) FAWOO LED LIGHT PANEL, (3) FAWOO AC/DC 12V ADAPTORS. (1) DIGICO LIGHTBOX. (1) 12 7/8" T5 FLUORESCENT STRIP W/ 6' POWER CORD. JESCO CONNECTION BLOCKS: (1) 3 POINT, (2) 6 POINTS.	FAWOO LED: LMS12-CS-WW-D-1000MM FAWOO LED: LMS12-CS-WW-D-1420MM FAWOO LED: LMS12-CS-WW-D-64MM FAWOO LED: 12V5A/MCW480B-15 FAWOO LED: 4 3/8" X 18 1/4" LED PANEL DIGICO: 19 1/2" X 52 1/4" LED PANEL HERA: FS12/SPC/XL JESCO: DB-CV-DC/AMP3 JESCO: DB-CV-DC/AMP6	8 WATT, T5, MINIATURE BI-PIN BASE, PREHEAT START LINEAR FLUORESCENT, 3000K, 85 CRI, 7,500 HRS. LED - 5300K	144 WATTS
SL	PINK ARMOIRE FIXTURE (2) 7w 22.24", (3) 11w 33.93" 3000K LINKABLE LED STICK LIGHTS WITH 90 DEGREE BEAM ANGLE ALLUMINUM FINISH. 45DEG MOUNTING CLIPS (2) PER FIXTURE, (2) POWERFEED CONNECTORS, (1) 75 WATT PLUG AND 8' CORD POWER SUPPLY, (1) 6" CONNECTING CABLE, (2) CONNECTOR CLIPS	FEELUX: DIVA 2 (2) NDV7T3000K24, (3) NDV11T3000K24 (1) NDVPTG(6") , (2) NDVPC (10) NDV-BRACKET2, (2) NDV-BRACKET3 (2) NDV-CAP, (1) FLC75-24V/T	3.5 WATT/FT INTEGRAL 3000K 80 CRI 40,000 HR	75 WATTS
SM	BEAUTY CABINET LIGHT USED IN SHELVES 12 13/16" T5 MINI STRIP WITH 8' WHITE CORD (1) REMOTE BALLAST PER (5) FIXTURES	BARTCO: BFLVS-8	8 WATT, T5 MINIATURE BI-PIN BASE, PREHEAT START LINEAR FLUORESCENT, 3000K, 85 CRI, 7,500HRS.	8 WATTS
SV	BEAUTY CABINET LIGHT USED IN SHELVES 46 1/16" T5 MINI STRIP WITH 8' WHITE CORD (1) REMOTE BALLAST PER (5) FIXTURES	BARTCO: BFLVS-28	28 WATT, T5 MINIATURE BI-PIN BASE, PROGRAMMED START LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000HRS.	28 WATTS
SX	BEAUTY CABINET LIGHT USED IN SHELVES 22 1/2" T5 MINI STRIP WITH 8' WHITE CORD (1) REMOTE BALLAST PER (5) FIXTURES	BARTCO: BFLVS-14	14 WATT, T5 MINIATURE BI-PIN BASE, PROGRAMMED START LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000HRS.	14 WATTS
SY	BEAUTY CABINET LIGHT USED IN SHELVES 34 1/4" T5 MINI STRIP WITH 8' WHITE CORD (1) REMOTE BALLAST PER (5) FIXTURES	BARTCO: BFLVS-21	21 WATT, T5 MINIATURE BI-PIN BASE, PROGRAMMED START LINEAR FLUORESCENT, 3000K, 85 CRI, 20,000HRS.	21 WATTS
T1	HORIZONTAL METAL HALIDE TRACK FIXTURE, BLACK FINISH, W/ CLEAR FLOOD REFLECTOR AND HEXCELL LOUVER, INTEGRAL ELECTRONIC BALLAST	AMERLUX: CYLT20-MM-E-BT-CTB-120-FL-HEX	20 WATT, T3.5, PGJ5 BASE, METAL HALIDE, CLEAR, 3000K, 85 CRI, 12000 HRS.	26 WATTS
T2	PAR30 FRONT LOADING GIMBAL RING TRACK HEAD, MATTE WHITE FINISH	CON-TECH: CTL2830P-40 JUNO: V689WH-50, HALO: L1730P-50 INDY: 133T-W-50	40 WATT, PAR30, MEDIUM SCREW BASE, IRC, FLOOD 25°, 42,000 HRS.	40 WATTS
T8	PAR30 METAL HALIDE TRACK HEAD, INTEGRAL ELECTRONIC BALLAST, WHITE FINISH, HIGH CEILING (14'-16')	JUNO: TM2102EWH HALO: L5130-35EP CON-TECH: CTL1610/35-MHP INDY: 493TE-W	30 WATT, PAR30, MEDIUM BASE, METAL HALIDE, CLEAR, 3000K, 85 CRI, SPOT 10°, 9000 HRS.	46 WATTS
TN	VERTICAL LED TRACK FIXTURE, WHITE FINISH, W/ 15 DEGREE OPTIC (15 DEGREE) DIMMABLE VIA 2-WIRE FORWARD PHASE (MLV/TRIAC)	AMERLUX: HORNET-HP-21-LED-E-WT-CTW-120-SP-3000-DIM-TRIAC	21 WATT INTEGRAL 3000K PHILIPS LUMILED 85 CRI 50,000 HR	21 WATTS
TP	VERTICAL LED TRACK FIXTURE, BLACK FINISH, W/ 15 DEGREE OPTIC (15 DEGREE)	AMERLUX: HORNET-HP-21-LED-E-BT-CTB-120-SP-3000	21 WATT INTEGRAL 3000K PHILIPS LUMILED 85 CRI 50,000 HR	21 WATTS
TR	SURFACE MOUNTED SINGLE CIRCUIT TRACK, MATTE BLACK FINISH	CON-TECH: LT2B, LT4B, LT6B, LT8B as required	-	-
TS	SURFACE MOUNTED SINGLE CIRCUIT TRACK, MATTE WHITE FINISH	CON-TECH: LT2P, LT4P, LT6P, LT8P as required	-	-
WC1	ONE LIGHT DECORATIVE SCONCE IN POLISHED NICKEL FINISH & CUSTOM HOT PINK RIBBON SHADE	CIRCA: DEAN SINGLE ARM SCONCE W/ POLISHED NICKEL FINISH ITEM# AM2000PN-NP HEIGHT: 12 3/4" ; WIDTH: 8 1/4" BACKPLATE: 3 1/2" X 4 1/2" DEPTH: 10 1/4"	20 WATT, A19, MEDIUM BASE, CFL, 2700K, 82CRI 10,000HRS	20 WATTS
WC2	ONE LIGHT DECORATIVE SCONCE IN POLISHED NICKEL FINISH & CUSTOM CREAM LINEN SHADE W/ PINK VELET TRIM TOP AND BOTTOM	CIRCA: DEAN SINGLE ARM SCONCE W/ POLISHED NICKEL FINISH ITEM# AM2000PN-NP HEIGHT: 12 3/4"; WIDTH: 8 1/4" BACKPLATE: 3 1/2" X 4 1/2" DEPTH: 10 1/4"	20 WATT, A19, MEDIUM BASE, CFL, 2700K, 82CRI 10,000HRS	20 WATTS
WD1	FIVE LIGHT DECORATIVE SCONCE IN POLISHED NICKEL FINISH	METROPOLITAN LIGHTING-MAGIQUE FIVE LIGHT BATH IN POLISHED NICKEL ITEM #N2755-613 HEIGHT: 26"; WIDTH: 6"; DEPTH: 4"	15 WATT, B 10 1/2, CANDELABRA BASE, HALOGEN, 2250 HRS.	75 WATTS
X6	THERMOPLASTIC EXIT SIGN, UNIVERSAL MOUNTING CEILING/WALL, LED LAMPS AND INTEGRAL BATTERY BACK UP FOR 90 MINUTES	LIGHTALARMS: QLXN500R-N ASTRALITE: TP-CSA-R-W (CSA APPROVED) HIGH-LITES: BP-PLED-5-R STANPRO: RMS-O-WH-IB (RUNNING MAN)	LED	4 WATTS
X9	RECESSED EMERGENCY LIGHT FOR SALES FLOOR USE, ADJUSTABLE LAMP, INTEGRAL BATTERY FOR EMERGENCY OPERATION FOR 90 MINUTE BATTERY BACK-UP	CONTECH: REX3-SF-R-EM-P EXITRONIX: C90Z-CR-WB-RC-ZC-WH-CSA-120 (CSA APPROVED) STANPRO: RMEA-OWH-IB-(RUNNING MAN)	(1) 8W HALOGEN	8 WATTS
XC	SINGLE FACE ADJUSTABLE RECESSED OR WALL MOUNT LED EDGE-LIT EXIT SIGN, WITH 90 MINUTE BATTERY BACK-UP. WHITE FINISH WITH RED LETTERING ON CLEAR FACEPLATE.	CONTECH: REX3-SF-R-EM-W EXITRONIX: C90Z-CR-WB-RC-ZC-BK-CSA-120 (CSA APPROVED) STANPRO: RMEA-O-BK-IB (RUNNING MAN)	LED	3 WATTS
XE	SINGLE FACE ADJUSTABLE RECESSED OR WALL MOUNT LED EDGE-LIT EXIT SIGN, WITH 90 MINUTE BATTERY BACK-UP. BLACK FINISH WITH RED LETTERING ON CLEAR FACEPLATE.	CONTECH: REX3-SF-R-EM-B EXITRONIX: C90Z-CR-WB-RC-ZC-BK-CSA-120 (CSA APPROVED) STANPRO: RMEA-O-BK-IB (RUNNING MAN)	LED	3 WATTS
XJ	FULLY RECESSED EMERGENCY LIGHT 90 MIN BATTERY BACK UP. WHITE FINISH 2 (35W) MR11 LAMPS	APERION: APR-25-LC-UI	35 WATT, MR11, 2 PIN GU 4 BASE, QUARTZ HALOGEN, FLOOD 30°, 4,000HRS.	70 WATTS
ZQ	CASHWRAP TABLE LAMP	OSM VENDOR (TBD)	20 WATT A19 MEDIUM BASE COMPACT FLUORESCENT LAMP 2700K, 82 CRI, 10,000 HRS	20 WATTS

NOTES:

1. ALL FIXTURES ARE FURNISHED BY LSD&C UNLESS OTHERWISE NOTED.
2. ALL LIGHT FIXTURES AND WIRING METHODS WITHIN PLENUM CEILING SHALL BE "PLENUM APPROVED" AS PER LOCAL ORDINANCES.
3. ALL LIGHT FIXTURES WITH 'EM' AFTER FIXTURE DESIGNATION SHALL BE PROVIDED WITH AN EMERGENCY BALLAST, PRODUCING A MINIMUM OF 1000 LUMENS FOR ONE (1) 48" LAMP.
4. ALL FIXTURES SHALL BE 120 VOLT UNLESS OTHERWISE NOTED.

LIGHT FIXTURE SCHEDULE - VICTORIA'S SECRET

NTS

05N-E0401-A00-SCHD

A
10/28/13

Thorson • Baker + Associates
CONSULTING ENGINEERS
3030 West Streetsboro Road (330) 659-6688 Ph.
Richfield, Ohio 44286 (330) 659-6675 Fax

Limitedbrands
LIMITED STORE PLANNING, INC.
d/b/a STORE DESIGN & CONSTRUCTION
Three Limited Parkway · Columbus, Ohio 43230
Telephone: 614.415.7000 · Fax: 614.415.7349

PROHIBITION OF REUSE:
THESE DRAWINGS AND SPECIFICATIONS WERE PREPARED FOR USE ON A SPECIFIC SITE, CONTEMPORANEOUSLY WITH THEIR ISSUE DATE, THEY ARE NOT INTENDED FOR USE ON A DIFFERENT PROJECT OR AT A LATER DATE. ANY REUSE, REPRODUCTION OR MODIFICATION OF THESE DRAWINGS AND SPECIFICATIONS, OR ANY PORTION THEREOF, ON ANOTHER PROJECT IS PROHIBITED AND CONTRARY TO LAW UNLESS EXPRESSLY AUTHORIZED IN WRITING BY THE LIMITED BRANDS COMPANY, INC. (D/B/A LIMITED STORE PLANNING, INC. OR LSD&C) LIMITED STORE DESIGN AND CONSTRUCTION ("LSD").

THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSD&C AND SHALL NOT BE DEPLOYED IN ANY MANNER WHATSOEVER, EXCEPT BY WRITTEN AGREEMENT WITH LSD&C. THEY SHALL NOT BE ASSIGNED TO ANY THIRD PARTY WITHOUT THE PRIOR WRITTEN CONSENT OF LSD&C. ALL COMMON LAW, STATUTORY AND OTHER RESERVED RIGHTS, INCLUDING COPYRIGHT, IN THE DRAWINGS AND SPECIFICATIONS SHALL BE RETAINED BY LSD&C. ALL REPRODUCTIONS OF THESE DRAWINGS AND SPECIFICATIONS MUST BE RETURNED TO LSD&C UPON COMPLETION OF THEIR INTENDED USE, UNLESS OTHERWISE AGREED TO BY LSD&C.

THESE DRAWINGS AND SPECIFICATIONS ARE COPYRIGHTED AND SUBJECT TO COPYRIGHT PROTECTION AS AN "ARCHITECTURAL WORK" UNDER SEC. 102 OF THE COPYRIGHT ACT, 17 U.S.C. §1 AS AMENDED DECEMBER 1990. THE ARCHITECT OF RECORD DETERMINED IN STATE WHERE THE PROJECT IS LOCATED MAY BE DIFFERENT THAN THOSE SHOWN HEREIN. THE COPYRIGHT PROTECTION INCLUDES WITHOUT LIMITATION, THE OVERALL FORM, ARRANGEMENT AND COMPOSITION OF SPACES AND ELEMENTS OF THE DESIGN INCLUDING BUT NOT LIMITED TO INDIVIDUAL WALLS, FIXTURES, WINDOWS, DOORS, COLUMNS, AND THE ARRANGEMENT OF SUCH ITEMS. THIS PROTECTION INCLUDES ALL FORMS AND MEDIA NOW KNOWN OR LATER DEVELOPED, INCLUDING BUT NOT LIMITED TO, PRINTED MATERIALS AND ELECTRONIC FILES. UNAUTHORIZED USE OF THESE DRAWINGS AND SPECIFICATIONS MAY RESULT IN CESSATION OF CONSTRUCTION, BUILDING SEIZURE, AND/OR MONETARY DAMAGES.

PROJECT INFORMATION:

010500485

VICTORIA'S SECRET
CAROLINA PLACE
11025 CAROLINA PLACE PKWY
SPACE B-14
PINEVILLE, NC 28134

REFRESH | PACKAGE: PKG II
GENERATOR | DRAWING 2013 (R1315a)/142Fa
A/E PROJECT #: 2007684009
NMA/ANGELS
00059286

SCOPE: DESIGN TYPE:
LSD&C PROJECT #:

REVISIONS:

REQUIRED BY:	DATE

ELITE CONSTRUCTION GROUP
LAKE ~~JACKSON, TX~~
PHONE: ~~979-285-0712~~
NOTE: ~~THESE PRINTS HAVE BEEN~~ REDUCED BY 50 PERCENT SCALE WILL ~~BE 50 PERCENT OF WHAT IS~~ NOTED ON PLANS

DATE ISSUED: 9/26/14
DESIGNED BY: RDW
DRAWN BY: TBA
CHECKED BY: JDM

ELECTRICAL LIGHT FIXTURE SCHEDULE

DRAWING NUMBER:
E04.01