

E. ALUMINUM-FRAMED ENTRANCES & STOREFRONTS:

- GENERAL: INSTALL G.C. SUPPLIED EXTRUDED ALUMINUM ENTRANCE SYSTEM WITH DOORS, FRAMES, HARDWARE, AND ACCESSORIES AS REQUIRED FOR COMPLETE WEATHERTIGHT INSTALLATION.
- STANDARDS: COMPLY WITH ARCHITECTURAL ALUMINUM MANUFACTURERS ASSOCIATION (AAMA) ALUMINUM FRONT AND ENTRANCE MANUAL.
- CODES AND REGULATIONS: COMPLY WITH APPLICABLE CODES AND REGULATIONS.
- SUBMITTALS: NOT REQUIRED.
- INSTALLATION WARRANTY.
- MANUFACTURER: OLD CASTLE (OR APPROVED EQUIVALENT)
- STOREFRONT: EXTRUDED ALUMINUM ENTRANCE SYSTEM AS INDICATED ON DRAWINGS.
 - ALUMINUM STRUCTURE FOR APPLICATION OF FINISH AS SPECIFIED IN FINISH SCHEDULE, BUT NOT LESS THAN EXTRUDED ALUMINUM, ASTM B221, 6061 OR 6063 ALLOY AND T5 OR T6 TEMPER
 - FINISH: BLACK #760
 - GLAZING: ASTM C1048, PROVIDE FULLY TEMPERED SELECT GLAZING QUALITY CLEAR FLOAT GLASS; NOMINAL 1/2" SAFETY GLASS UNLESS OTHERWISE INDICATED.
 - APPLIES: GLAZING FILM: SUPPLY & APPLY 3M FILM ON ALUMINUM FRAMED STOREFRONT GLASS WHERE INDICATED ON DRAWINGS.
 - GLAZING ACCESSORIES: OR TYPE RECOMMENDED BY MANUFACTURER TO SUIT SECURITY LOCATIONS AND APPLICATIONS FOR DRY GLAZING INSTALLATION.
- MISCELLANEOUS MATERIALS:
 - STEEL REINFORCEMENT AND BRACKETS MANUFACTURER'S STANDARD WITH MINIMUM 2% ZINC. HOT-DIP ZINC COATING, ASTM A123, APPLIED AFTER FABRICATION.
 - BITUMINOUS PAINT: COLD-APPLIED PLASTIC, SSPC PAINT 12, COMPOUNDED FOR 30 MIL THICKNESS PER COAT.
 - FLASHING: INSTALL SUB-SILL FLASHING MEMBERS; MINIMUM 22 GAGE SHEET ALUMINUM OF SIZES AND SHAPES INDICATED AND AS REQUIRED TO DRAIN WATER TO EXTERIOR; ADJACENT ALUMINUM MEMBER FINISH TO MATCH ADJACENT GLASS; ADJACENT ALUMINUM MEMBER FINISH TO MATCH ADJACENT GLASS; ADJACENT ALUMINUM MEMBER FINISH TO MATCH ADJACENT GLASS; ADJACENT ALUMINUM MEMBER FINISH TO MATCH ADJACENT GLASS.
 - ANCHORING DEVICES: CAPTION RESISTANT TYPE CAPABLE OF SUPPORTING ENTRANCE SYSTEM UNDERIMPOSED DESIGN LOADS; DESIGN TO ALLOW ADJUSTMENTS OF SYSTEM PRIOR TO BEING PERMANENTLY FASTENED IN PLACE.
- FABRICATION:
 - ACCURATELY FIT TOGETHER JOINTS AND CORNERS; MATCH COMPONENTS ENSURING CONTINUITY OF LINE AND DESIGN; ENSURE JOINTS AND CONNECTIONS ARE FLUSH 1/64th INCH MAX. AND WEATHERPROOF; NO CAULK AT ANY JOINTS OR CONNECTIONS, NO EXCEPTIONS!
 - SEPARATE DISSIMILAR MATERIALS WITH BITUMINOUS PAINT OR PREFORMED SEPARATORS WHICH WILL PREVENT CORROSION.
 - INSTALLATION: INSTALL ALUMINUM FRAMED STOREFRONT ASSEMBLIES, INCLUDING ENTRANCES, IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS AND TO MEET DESIGN REQUIREMENTS INDICATED FOR WEATHERTIGHT INSTALLATION.
 - ENSURE ASSEMBLIES ARE PLUMB, LEVEL AND FREE OF WARP OR TWIST; MAINTAIN DIMENSIONAL TOLERANCES AND ALIGNMENT WITH ADJACENT WORK.
 - USE SUFFICIENT ANCHORAGE DEVICES TO SECURELY AND RIGIDLY FASTEN ASSEMBLIES TO BUILDING.
 - INSTALL HARDWARE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS, USING PROPER TEMPLATES. COORDINATE INSTALLATION OF CYLINDERS WITH SECTION 0870.
 - INSTALL SILL MEMBERS AND THRESHOLDS IN BED OF COMPOUND, JOINT FILLERS OR GASKETS TO PROVIDE WEATHERTIGHT CONSTRUCTION.
 - GLASS INSTALLATION: COMPLY WITH GANA GLAZING MANUAL AND GLAZING MANUFACTURER INSTRUCTIONS. DO NOT ALLOW GLASS TO TOUCH METAL SURFACES.

DIVISION 9 - FINISHES

A. GYPSUM DRYWALL:

- FURNISH AND INSTALL ALL GYPSUM DRYWALL AND SYSTEMS COMPLETE WITH PARTITION FRAMING, CEILING SUSPENSION SYSTEMS AND RELATED ACCESSORIES, PARTS, MATERIALS, ETC. AS SHOWN ON DRAWINGS AND AS SPECIFIED. INSTALL ALL MATERIALS PER MANUFACTURER'S SPECIFICATIONS AND RECOMMENDATIONS.
- GYPSUM DRYWALL: U.S. GYPSUM 5/8" THICK FIRE CODE SHEETROCK (TYPE 'X') PANELS OF STANDARD QUALITY. GENERAL CONTRACTOR MAY USE NON-RATED 5/8" THICK BOARD IN AREAS OF STORAGE, ALL OTHERS TO BE RATED TO MEET STATE AND LOCAL CODES. ALWAYS USE TYPE 'X' ON TENANT SEPARATION WALLS.
- FASTENERS: DRYWALL SCREWS OF PROPER SIZE AND TYPE, PER MANUFACTURER'S RECOMMENDATIONS.
- METAL ACCESSORIES: U.S. GYPSUM OR GOLD BOND SYSTEM OF COMPONENTS AND JOINT TAPE.
- JOINT TREATMENT: U.S. GYPSUM OR GOLD BOND SYSTEM OF COMPONENTS AND JOINT TAPE.

B. CERAMIC TILE:

- CERAMIC TILE AS SPECIFIED IN FINISH SCHEDULE AND RESPONSIBILITY SCHEDULE. (IF APPLICABLE)
- INSTALL CERAMIC TILE USING RECOMMENDED METHODS OF THE TILE CONTRACTORS ASSOCIATION AND THE TILE COUNCIL OF AMERICA.
- INSTALL CERAMIC TILE USING GROUT AND JOINT SPACING SPECIFIED IN FINISH SCHEDULE.
- ADHESIVE IS TO BE PROVIDED AND INSTALLED BY GENERAL CONTRACTOR (PER MANUFACTURER'S SPECIFICATIONS).
- CAREFULLY CLEAN ALL WORK AND REPLACE OR REPOINT ANY DAMAGED WORK AND LEAVE IN PERFECT CONDITION. USE NO ACID, AGENT OR DEVICE THAT WILL HARM SURFACE. CONSULT WITH OWNER'S CONSTRUCTION MANAGER FOR INSTRUCTIONS (DO NOT POLISH CERAMIC TILE).
- CERAMIC TILES ARE TO BE SET WITHOUT TRIPPING HAZARD TO CUSTOMERS OR STAFF.
- THE GENERAL CONTRACTOR IS RESPONSIBLE TO CORRECT RAISED CERAMIC TILES FOR THE ENTIRE DURATION OF THE WARRANTY PERIOD AT THE DIRECTION OF THE OWNER'S CONSTRUCTION MANAGER.
- CEILING SYSTEMS:
 - FURNISH AND INSTALL CEILING SYSTEM COMPLETE WITH SUSPENSION SYSTEM AND RELATED ACCESSORIES AS SHOWN ON DRAWINGS AND AS SPECIFIED.
 - SUSPENSION SYSTEMS SHALL BE ADEQUATE TO SUPPORT LIGHT FIXTURES, CEILING, GRILLES, DIFFUSERS AND OTHER NORMAL ACCESSORIES; PROVIDE SYSTEM TO COMPONENTS FROM A SINGLE MANUFACTURER.
 - INSTALL CEILING AND SUSPENSION SYSTEMS IN STRICT ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS. FINISH CEILING SHALL BE LEVEL, WITH JOINTS SNUG AND SQUARE, AND TILES OR PANELS IN PERFECT CONDITION.
 - MATERIALS AND FINISHES:
 - REFER TO DRAWINGS FOR LOCATION OF SPECIFIED MATERIALS AND FINISHES WHEN APPLICABLE.
 - NON-SALES CEILING: AS SCHEDULED BY LOCAL CLASS "A" RATING.
 - WHEN A ONE-HOUR FIRE-RATED CEILING ASSEMBLY IS REQUIRED BY LANDLORD, STATE OR LOCAL CODES, THEN GENERAL CONTRACTOR IS TO CONFORM WITH UNDERWRITER'S LABORATORIES TEST FOR A ONE-HOUR RATED ASSEMBLY AS SCHEDULED.
 - G.C. TO PROVIDE ONE BOX OF THE SPECIFIED CEILING TILES ON SITE FOR FUTURE USE.
- VINYL PLANK FLOORING:
 - GENERAL: G.C. TO INSTALL OWNER SUPPLIED VINYL STRIP FLOORING SYSTEM WITH ACCESSORIES AS REQUIRED FOR COMPLETE FINISHED INSTALLATION.
 - PROJECT CONDITIONS: PRIOR TO INSTALLATION OF ANY FLOORING, GC MUST ENSURE THAT THE JOBSITE AND SUB-FLOOR MEET THE REQUIREMENTS OF THE FOLLOWING INSTRUCTION.
 - G.C. TO PERFORM MOISTURE TEST ON ALL CONCRETE FLOORS AS DIRECTED BY NMFA AND INSTALL BOSTIK MVP4 VAPOR BARRIER. MOISTURE CONTENT OF WOOD SUB-FLOOR MUST NOT EXCEED 12% AND CONCRETE MOISTURE CONTENT MUST NOT EXCEED 3lbs.
 - G.C. TO PROVIDE MOISTURE TEST REPORT TO CONSTRUCTION MANAGER IMMEDIATELY AFTER DEMOLITION AND/OR 1 WEEK PRIOR TO FLOOR INSTALLATION. IF THE G.C. FAILS TO PROVIDE REPORT, ANY FLOOR FAILURE ATTRIBUTED TO MOISTURE, IT WILL BE THE RESPONSIBILITY OF THE G.C. TO REPLACE (LABOR AND MATERIAL).
 - ALL WORK INVOLVING WATER OR MOISTURE SHOULD BE COMPLETED BEFORE FLOOR INSTALLATION.
 - ROOM TEMPERATURE AND HUMIDITY OF INSTALLATION AREA SHOULD BE CONSISTENT WITH NORMAL, YEAR-ROUND LIVING CONDITIONS FOR AT LEAST A WEEK BEFORE INSTALLATION. ROOM TEMPERATURE OF 60 TO 70 DEGREE F AND HUMIDITY RANGE OF 40 TO 60% IS RECOMMENDED.
 - G.C. TO STORE FLOORING AT INSTALLATION SITE FOR 72 HOURS BEFORE INSTALLATION. FLOORING IS TO BE STORED TO ALLOW ROOM TEMPERATURE AND HUMIDITY. DO NOT STORE DIRECTLY ON CONCRETE OR NEAR OUTSIDE WALLS. THIS FLOORING MAY NOT BE ACCEPTABLE FOR FULL BATHROOM INSTALLATIONS BECAUSE OF MOISTURE ASSOCIATED WITH SUCH LOCATIONS.
 - COMMENCEMENT OF WORK IS ACCEPTANCE OF CONDITIONS.
 - MANUFACTURERS: REFER TO FINISH SCHEDULE.
 - ADHESIVE: AS RECOMMENDED BY MANUFACTURER TO ENSURE MAXIMUM DURABILITY OVER TIME; NONTOXIC, WATERPROOF TYPE SUITABLE FOR FLOORING, SUBSTRATE, AND ACCEPTABLE TO APPLICABLE AUTHORITIES.
 - MOISTURE VAPOR PROTECTION: BOSTIK MVP4 MOISTURE BARRIER OR AS RECOMMENDED BY MANUFACTURER; ONE-PART, TROWEL APPLIED, ELASTOMERIC, MOISTURE CURE URETHANE MEMBRANE. APPLY WITH 3/16" X 5/32" V-NOTCH TROWEL IS RECOMMENDED.

F. WOOD STRIP FLOORING:

- GENERAL: PROVIDE SHOP FINISHED PRE-ENGINEERED WOOD STRIP FLOORING SYSTEM WITH ACCESSORIES AS REQUIRED FOR COMPLETE FINISHED INSTALLATION.
- SUBMITTALS: FURNISH MANUFACTURER'S LITERATURE AND SAMPLES OF WOOD FLOORING AND EXPOSED ACCESSORIES, INCLUDING FINISH.
- PROJECT CONDITIONS: PRIOR TO INSTALLATION OF ANY FLOORING, GC MUST ENSURE THAT THE JOBSITE AND SUB-FLOOR MEET THE REQUIREMENTS OF THE FOLLOWING INSTRUCTION.
 - G.C. TO PERFORM MOISTURE TEST ON ALL CONCRETE FLOORS AS DIRECTED BY NMFA AND INSTALL BOSTIK MVP4 MOISTURE VAPOR PROTECTION. SUB-FLOOR MUST BE COMPLETELY DRY. THE MOISTURE CONTENT DIFFERENCE SHOULD BE NO MORE THAN 4% BETWEEN THE ENGINEERED WOOD FLOOR AND CONCRETE SUBFLOOR.
 - G.C. TO PROVIDE MOISTURE TEST REPORT TO CONSTRUCTION MANAGER IMMEDIATELY AFTER DEMOLITION AND/OR 1 WEEK PRIOR TO FLOOR INSTALLATION. IF THE G.C. FAILS TO PROVIDE REPORT, ANY FLOOR FAILURE ATTRIBUTED TO MOISTURE, IT WILL BE THE RESPONSIBILITY OF THE G.C. TO REPLACE (LABOR AND MATERIAL).
 - ALL WORK INVOLVING WATER OR MOISTURE SHOULD BE COMPLETED BEFORE FLOOR INSTALLATION.
 - ROOM TEMPERATURE AND HUMIDITY OF INSTALLATION AREA SHOULD BE CONSISTENT WITH NORMAL, YEAR-ROUND LIVING CONDITIONS FOR AT LEAST A WEEK BEFORE INSTALLATION. ROOM TEMPERATURE OF 65 TO 75 DEGREE F AND HUMIDITY RANGE OF 40 TO 60% IS RECOMMENDED.
 - G.C. TO STORE FLOORING AT INSTALLATION SITE FOR 72 HOURS BEFORE INSTALLATION TO ALLOW FLOORING TO ADJUST TO ROOM TEMPERATURE AND HUMIDITY. DO NOT STORE DIRECTLY ON CONCRETE OR NEAR OUTSIDE WALLS. THIS FLOORING MAY NOT BE ACCEPTABLE FOR FULL BATHROOM INSTALLATIONS BECAUSE OF MOISTURE ASSOCIATED WITH SUCH LOCATIONS.
 - COMMENCEMENT OF WORK IS ACCEPTANCE OF CONDITIONS.
 - MANUFACTURERS: REFER TO FINISH SCHEDULE.
 - WOOD: AS INDICATED ON DRAWINGS, TONGUE AND GROOVED EDGES WITH SHOP APPLIED ACRYLIC IMPREGNATED FINISH INTENDED FOR DIRECT ADHESIVE APPLICATION TO CONCRETE.

- ADHESIVE: AS RECOMMENDED BY MANUFACTURER; URETHANE BASED ADHESIVE SHOULD BE USED EXCLUSIVELY: BOSTIK BEST, BST, EFA OR TKO.
- MOISTURE VAPOR PROTECTION: BOSTIK MVP4 MOISTURE VAPOR PROTECTION OR AS RECOMMENDED BY MANUFACTURER; ONE-PART, TROWEL APPLIED, ELASTOMERIC, MOISTURE CURE URETHANE MEMBRANE. APPLY WITH 3/16" X 5/32" V-NOTCH TROWEL IS RECOMMENDED.
- SUBFLOOR FILLER: WHITE PREMIXED LATEX-CEMENT LATEX REQUIRING WATER ONLY TO PRODUCE CEMENTITIOUS PASTE.
- DIVIDER STRIPS: TYPE AS INDICATED, AS SELECTED BY ARCHITECT FROM MANUFACTURER'S FULL RANGE OF EDGE STRIPS WHERE NOT OTHERWISE INDICATED.
- PREPARATION: BROOM CLEAN SUBSTRATE SURFACE AND ENSURE FLOOR SURFACE IS SMOOTH AND FLAT TO PLUS OR MINUS 1/8" PER 10'-0", FREE OF OIL, GREASE, DIRT AND FOREIGN SUBSTANCES. USE LATEX FILLER TO PATCH CRACKS AND SMALL HOLES, AND FOR MINOR LEVELING.
 - GRIND CONCRETE WHERE RIDGES AND IRREGULARITIES PROVIDE UNSATISFACTORY SUBSTRATE FOR WOOD STRIP FLOORING. BUFF CONCRETE WITH AN 80 GRIT SCREEN, THEN VACUUM AND WIPE THOROUGHLY WITH LACQUER THINNER.
- INSTALLATION: COMPLY WITH MANUFACTURER'S RECOMMENDATIONS AND INSTALLATION INSTRUCTIONS FOR WOOD STRIP FLOORING.
 - INSPECT FLOORING MATERIAL FOR DEFECT TYPE, QUANTITY AND DAMAGE.
 - PROVIDE AT LEAST 1/2" EXPANSION SPACE BETWEEN FLOORING AND ALL WALLS AND VERTICAL OBJECTS.
 - ENSURE JOINTS OF WOOD FLOORING ARE IN LINE; ENSURE FULL ADHESIVE CONTACT FOR PERMANENT BOND TO SUBSTRATE. WHEN INSTALLING DIRECT TO CONCRETE, IT IS RECOMMENDED THAT PAINTERS TAPE BE USED TO HOLD THE FLOORING TOGETHER WHILE ADHESIVE IS WET. THIS WILL KEEP THE FLOOR TIGHT AND CRACKS TO A MINIMUM. REMOVE BLUE TAPE WITHIN 8 HOURS.
 - LAY FLOORING SYMMETRICAL ABOUT ROOM CENTER LINE; FIT NEATLY TO VERTICAL INTERRUPTIONS.
 - ALL BOARDS THAT ARE CUT SHOULD BE HAND BEVELED OR DRAGGED, AND REMOVE THE COLOR FROM THE FLOORING.
 - BOARDS THAT MEET PERPENDICULAR OR AT ANY OTHER ANGLE ARE TO BE TONGUE AND GROOVED TOGETHER.
 - CLEAN ALL ADHESIVE OFF THE FINISHED FLOORING WITH MINERAL SPIRITS MAKING SURE NOT TO RUB TOO AGGRESSIVELY WHICH COULD DAMAGE THE FINISH AND/OR REMOVE THE COLOR FROM THE FLOORING.
 - PROVIDE DIVIDER STRIPS WHERE FLOORING TERMINATES WITH TILE OR OTHER FLOOR FINISHES.
 - DIVIDER STRIPS MANUFACTURER: MANHATTAN AMERICAN TERRAZZO STRIP COMPANY P.O. BOX 72433 OLD 421 ROAD STALEY, NORTH CAROLINA 27355 (336) 622-4247; FAX: (336) 622-4160 matsens@aol.com
- PROVIDE MAXIMUM 1/12 SLOPE WHERE FINISHED FLOOR SURFACE CHANGES LEVEL BETWEEN WOOD FLOORING AND ADJACENT FLOORING.

F. RESILIENT SHEET FLOORING:

- GENERAL: PROVIDE RESILIENT SHEET FLOORING WITH ACCESSORIES AS REQUIRED FOR COMPLETE FINISHED INSTALLATION.
- SUBMITTALS: FURNISH PRODUCT DATA AND SAMPLES OF EACH TYPE OF FLOORING COLOR AND PATTERN SELECTED AND EACH TYPE OF EXPOSED INTEGRAL BASE ACCESSORY.
- PROJECT CONDITIONS: ENSURE FLOOR SURFACES ARE SMOOTH AND FLAT WITH MAXIMUM DEVIATION OF 1/8" IN 10'-0"; ENSURE CONCRETE FLOORS ARE DRY AND EXHIBIT NEGATIVE ALKALINITY, CARBONIZING AND DUSTING.
 - REFER TO FINISH SCHEDULE FOR LOCATION OF SPECIFIED MATERIALS AND FINISHES WHEN APPLICABLE.
 - FLAMMABILITY: 0.45 WATTS/SQ.CM. OR HIGHER, ASTM E648.
- EDGE STRIPS AND ACCESSORIES: RUBBER OR VINYL EDGE STRIPS MATCHING ROOM FLOOR FLOORING.
- SUBFLOOR/FILLER: WHITE PREMIXED LATEX-CEMENT PASTE DESIGNED FOR PROVIDING THIN SOLID SURFACE FOR LEVELING AND MINOR RAMMING OF SUBSURFACE TO ADJACENT FLOOR FINISHES. USE MATERIAL CAPABLE OF BEING APPLIED AND FEATHERED OUT TO ADJACENT FLOOR WITHOUT SPALLING.
- PRIMERS AND ADHESIVES: WATERPROOF NONTOXIC TYPES AS RECOMMENDED BY FLOORING MANUFACTURER FOR SPECIFIED MATERIAL AND APPLICATION.
- SEALER AND WAX: TYPE RECOMMENDED BY FLOORING MANUFACTURER FOR MATERIAL TYPE AND LOCATION.
- PREPARATION: CONFORM TO ASTM F710 AND MANUFACTURER'S RECOMMENDATIONS FOR PREPARATION; REMOVE SUBFLOOR RIDGES AND BUMPS; FILL LOW SPOTS, CRACKS, JOINTS, HOLES AND DEFECTS WITH SUBFLOOR FILLER.
- INSTALLATION: COMPLY WITH FLOORING AND BASE MANUFACTURER RECOMMENDATIONS AND INSTALLATION INSTRUCTIONS; SET FLOORING IN PLACE, PRESS WITH HEAVY ROLLER FOR FULL ADHESION; SCRIBE TO WALLS, COLUMNS, AND OTHER APPURTENANCES TO PRODUCE TIGHT JOINTS.
 - LAY FLOORING WITH MINIMUM SEAMS WITH PATTEN PARALLEL TO BUILDING LINES TO PRODUCE SYMMETRICAL PATTERN; TERMINATE RESILIENT FLOORING AT CENTERLINE OF DOOR OPENING WHERE ADJACENT FLOOR FINISH IS DISSIMILAR. INSTALL EDGE STRIPS AT UNPROTECTED OR EXPOSED EDGES.
- INTEGRAL COVE BASE: PROVIDE INTEGRAL COVE BASE INCLUDING COVE SUPPORT STRIP OR FILLER AND METAL TOP EDGE STRIP; INSTALL TOP EDGE STRIP LEVEL WITH FLOOR LINE, WITH TIGHTLY BUTTED JOINTS, MITERED CORNERS; USE LONGEST TOP EDGE PIECES AVAILABLE, MINIMUM 48" BETWEEN JOINTS.
- CLEANING: REMOVE EXCESS ADHESIVE FROM FLOOR, BASE AND WALL SURFACES.

G. VINYL RESILIENT TILE (NON-SALES):

- SEE FINISH SCHEDULE. BUTT BASE TO FLOOR AND WALL WITH NO GAPS.
- FILL ALL CRACKS, JOINTS, ETC. IN SUB-FLOOR WITH CRACK FILLER APPROVED BY FLOORING MANUFACTURER. INSTALL ALL MATERIALS WITH WATERPROOF TYPE ADHESIVES AS RECOMMENDED BY FLOORING MANUFACTURER FOR MATERIALS AND SURFACES INVOLVED.

H. PAINTING AND COATING

- THIS SPECIFICATION DEFINES THE REQUIREMENTS FOR SURFACE PREPARATION, COATING SYSTEMS, MINIMUM AND MAXIMUM DRY FILM THICKNESS, SPECIAL APPLICATION INSTRUCTIONS WHEN NECESSARY AND INSPECTION FOR PAINTING OF SPECIFIED SUBSTRATES.
- IF INSTRUCTIONS CONTAINED IN THIS SPECIFICATION, BID DOCUMENTS OR THE PAINTING SCHEDULE ARE AT VARIANCE WITH THE PAINT MANUFACTURER'S INSTRUCTIONS OR THE APPLICABLE STANDARDS AND CODES PUBLISHED BY SSPC OF OSHA, SURFACES SHALL BE PREPARED AND PAINT APPLIED TO MEET THE HIGHER STANDARD, AS DETERMINED BY THE DESIGN AUTHORITY.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR REQUESTING PROMPT CLARIFICATION WHEN INSTRUCTIONS ARE LACKING, CONFLICTS OCCUR IN THE SPECIFICATION AND/OR PAINT MANUFACTURER'S LITERATURE, OR THE PROCEDURE SPECIFIED IS NOT CLEARLY UNDERSTOOD. IN THE EVENT, THE CONTRACTOR FAILS TO RESOLVE THE CONFLICTS, WHICH MAY EXIST, HE SHALL BE RESPONSIBLE FOR HANDLING THE DISCREPANCIES IN A MANNER AS PRESCRIBED BY THE DESIGN AUTHORITY AT NO ADDITIONAL COST TO THE OWNER.
- ALL PERTINENT SAFETY REGULATIONS, BOTH THE OWNER'S AND OSHA'S SHALL BE ADHERED TO RIGIDLY. IN ADDITION, ALL SAFETY PRECAUTIONS NOTED ON THE MANUFACTURER'S PRODUCT DATA SHEETS AND LABELS SHALL BE OBSERVED FOR BOTH MATERIALS AND EQUIPMENT.
- THE APPLICATION SHALL LEAVE NO SAGS, RUNS OR HOLIDAYS. ANY DAMAGE IN ANY COAT SHALL BE REPAIRED TO CONFORM TO THIS SPECIFICATION PRIOR TO FINAL INSPECTION.
- WHERE REQUIRED, IMPERFECTIONS AND HOLES IN SURFACES TO BE COATED SHALL BE CLEANED AND REPAIRED ACCORDING TO HIGHEST INDUSTRY STANDARDS AND IN A MANNER APPROVED BY THE DESIGN AUTHORITY.
- ALL MATERIALS SPECIFIED FROM BENJAMIN MOORE & CO., AND ARE INTENDED TO ESTABLISH STANDARDS OF QUALITY AND GENERIC TYPES. COATING SUBSTITUTIONS ARE PROHIBITED.
- ALL COATING MATERIALS SHALL BE DELIVERED TO OTHER JOB SITE IN THE ORIGINAL AND UNOPENED CONTAINERS, PLAINLY MARKED WITH THE PROPER DESIGNATION OF THE PRODUCT, AS WELL AS THE NAME OF THE MANUFACTURER. ALL COATING MATERIALS AT THE JOB SITE SHALL BE SUBJECT TO INSPECTION BY THE OWNER'S REPRESENTATIVE.
- ALL PAINTING MATERIALS SHALL BE STORED IN A CLEAN, DRY WELL VENTILATED PLACE, PROTECTED FROM SPARKS, FLAME, DIRECT RAYS OF THE SUN, AND EXCESSIVE HEAT OR COLD. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR THE PROTECTION AND SAFETY OF MATERIALS STORED BY G.C. AT THE JOB SITE.
- PAINT ADDITIVES ARE PROHIBITED.
- COLORS FOR FINISHING SHALL BE AS SPECIFIED IN THE FINISH PAINTING SCHEDULE. OF THIS SPECIFICATION AND/OR THE PAINTING SCHEDULE SUBMITTED AS A PART OF THE SCOPE OF WORK DOCUMENTS WITH THE SCOPE OF WORK SCHEDULE TAKING PRECEDENCE. COLORS SHALL NOT BE SUBSTITUTED.
- SURFACES NOT TO BE PAINTED SHALL BE PROTECTED DURING CLEANING & PAINTING OPERATIONS.
- BEFORE ANY SURFACE IS COATED, IT SHALL BE CLEANED CAREFULLY OF ALL DUST, DIRT, GREASE, LOOSE RUST, MILL SCALE, OLD PAINT, ETC.
- ALL CLEANED METAL SHALL BE PRIME COATED, AS SPECIFIED, IMMEDIATELY AFTER CLEANING TO PREVENT NEW RUSTING OR OXIDATION OF CLEANED SURFACES.
- SURFACES:
 - SURFACE PREPARATION (ALL METAL AND WOOD SURFACES)
 - SOFTEN CLEANING (SSPC-SP-13): THIS IS A METHOD FOR REMOVING OIL, GREASE, DRIPPING FLUIDS FROM THE SURFACE. A COMPLETE DESCRIPTION OF THE PROCEDURES CAN BE FOUND IN STEEL STRUCTURES PAINTING COUNCIL SPECIFICATION "SSPC-SP-13 SOLVENT CLEANING"
 - EMULSIFIER SOLVENT CLEANING - ALL AREAS TO BE PAINTED SHOULD BE CLEANED THOROUGHLY WITH A SOLUTION OF OIL AND GREASE EMULSIFIER. THIS CLEANER EMULSIFIES ALL OF THE OILY SUBSTANCE CONVERTING IT TO SOAP AND FLOATS IT OUT OF THE SURFACE, THOROUGHLY SCRUB ALL AREAS UNTIL SURFACE APPEARS CLEAN, AND THE RINSE WELL WITH CLEAN WATER. THIS PROCESS SHOULD BE REPEATED TO ENSURE THAT THERE ARE NO OTHER OILY CONTAMINANTS REMAINING.
 - WALLS AND COLUMNS - EGGSHELL FINISH
 - PRIMER: APPLY ONE (1) COAT OF SUPER SPEC LATEX ENAMEL UNDERCOATER & PRIMER SEALER (PRODUCT # 253) AT A WET FILM THICKNESS OF 3.8 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.1 MILS PER COAT. (TINT FINISH COAT). PRIMER ONE SHADE LIGHTER THAN FINISH COAT.
 - FINISH: APPLY TWO (2) COATS OF REGAL SELECT PREMIUM INTERIOR PAINT EGGSHELL FINISH (549) AT A WET FILM THICKNESS OF 3.8 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.5 MILS PER COAT.
 - APPLICATION: BRUSH SMALL AREAS AND AROUND TRIM AND CEILING WITH PREMIUM QUALITY NYLON/POLYESTER BRUSH. FIRST COAT MAY BE SPRAYED, BUT BACKROLL WITH SOFT WOVEN COVER NO LARGER THAN 1/2" NAP TO MINIMIZE TEXTURE. SECOND COAT SHALL BE APPLIED BY ROLLER ONLY.
 - CEILINGS AND SOFFITS - FLAT FINISH
 - PRIMER: APPLY ONE (1) COAT OF SUPER SPEC LATEX ENAMEL UNDERCOATER & PRIMER SEALER (PRODUCT # 253) AT A WET FILM THICKNESS OF 3.6 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.1 MILS PER COAT. (TINT PRIMER ONE SHADE LIGHTER THAN FINISH COAT).
 - FINISH: APPLY TWO (2) COATS OF REGAL SELECT PREMIUM INTERIOR PAINT FLAT FINISH (547) AT A WET FILM THICKNESS OF 3.8 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.4 MILS PER COAT.
 - APPLICATION: BRUSH SMALL AREAS AND AROUND TRIM AND CEILING WITH PREMIUM QUALITY NYLON/POLYESTER BRUSH. FIRST COAT MAY BE SPRAYED, BUT BACKROLL WITH SOFT WOVEN COVER NO LARGER THAN 1/2" NAP TO MINIMIZE TEXTURE. SECOND COAT SHALL BE APPLIED BY ROLLER ONLY.
 - METAL DOORS AND METAL DOOR JAMBS - SEMI GLOSS FINISH
 - PRIMER: APPLY ONE (1) COAT OF SUPER SPEC HP ACRYLIC METAL PRIMER (P04) AT A WET FILM THICKNESS OF 4.0-4.5 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.7-2.3 MILS PER COAT. (TINT PRIMER ONE SHADE LIGHTER THAN FINISH COAT).
 - FINISH: APPLY TWO (2) COATS OF REGAL SELECT PREMIUM INTERIOR PAINT SEMI-GLOSS FINISH (551) AT A WET FILM THICKNESS OF 3.8 MILS PER COAT TO ACHIEVE A DRY FILM THICKNESS OF 1.4 MILS PER COAT.
 - APPLICATION: BRUSH APPLY WITH PREMIUM QUALITY NYLON/POLYESTER BRUSH. ALWAYS KEEP A WET EDGE DURING APPLICATION. FOR DOORS, A SOFT WOVEN COVER OF NO MORE THAN 1/2" IS RECOMMENDED FOR A SMOOTH APPEARANCE. A MAXIMUM OF ONE PINT PER GALLON OF CLEAN WATER MAY BE ADDED FOR A DESIRED CONSISTENCY AND FLOW.
- NOTES AND CAUTIONS
 - ENSURE PROPER CONDITIONS FOR APPLICATION - BEFORE ANY SURFACE IS COATED, ALL DUST, DIRT, GREASE, LOOSE RUST, MILL SCALE, LOOSE PAINT, ETC. IMPERFECTIONS AND HOLES IN SURFACES TO BE COATED SHALL BE CLEANED AND FILLED IN AN APPROVED MANNER.
 - ALL PROJECTS SHOULD BE INSPECTED - AT VARIOUS STAGES OF SURFACE PREPARATION AND COATING APPLICATION. INSPECTIONS SHOULD BE CARRIED OUT BY G.C. INSPECTION & OWNER'S REP. OR BY OUTSIDE INSPECTION FIRMS.
 - CLEAN ANY BOLTS AND PAINT THEM USING A BRUSH. COLORS SHOULD BE DEGREASED BEFORE PRIMING. THE PRIMER AND TOPCOATS SHOULD BE APPLIED BY BRUSH TO ACHIEVE COMPLETE AND UNIFORM COVERAGE.
 - MASK FAYING SURFACES AFTER PRIMING - IF FAYING SURFACES ARE TO BE PRIMED, THEY MUST BE MASKED AFTER PRIMING TO PREVENT TOPCOATING OF THE FAYING SURFACES. APPLICATION OF THE TOPCOAT TO A FAYING SURFACE MAY LEAD TO LOOSENING OF FRICTION JOINTS.
 - ENSURE ADEQUATE VENTILATION WHILE APPLYING AND CURING COATINGS IS IMPORTANT FOR HEALTH AND SAFETY REASONS AND TO ENSURE PROPER CURING OF THE COATING. WHEN APPLYING COATINGS IN CONFINED SPACES, SOLVENT VAPORS MAY ACCUMULATE, LEADING TO INTOXICATION OF WORKERS OR FIRE AND EXPLOSION. FLAMMABLE SOLVENTS AND THE AROMATIZED COATINGS ARE GENERALLY HEAVIER THAN AIR AND TEND TO SETTLE IN THE LOWEST AREAS OF CONFINED SPACE. CONSIDER THIS WHEN DESIGNING AND INSTALLING THE VENTILATION SYSTEM.
 - PAINT BEFORE INSTALLING HARDWARE.

I. CARPET:

- INSTALL OWNER FURNISHED CARPET; PROVIDE CARPET ACCESSORIES AS REQUIRED FOR COMPLETE FINISHED INSTALLATION.
- STANDARDS: COMPLY WITH CARPET AND RUG INSTITUTE (CRI) STANDARDS.
 - FLAMMABILITY: 0.45 WATTS/SQ.CM. OR HIGHER, ASTM E648.
- INSTALLATION: AS RECOMMENDED BY CARPET MANUFACTURER; UPON REQUEST, SUBMIT LETTER FROM CARPET MANUFACTURER STATING INSTALLER IS ACCEPTABLE.
- ADHESIVE: NONTOXIC TYPE RECOMMENDED BY CARPET AND UNDERLAY MANUFACTURERS TO SUIT APPLICATION AND EXPECTED SERVICE.
- LEVELING AND RAMPING MATERIAL: LATEX-CEMENT MATERIAL, DESIGNED FOR PROVIDING THIN SOLID SURFACE FOR LEVELING AND MINOR RAMMING OF SUBSURFACE TO ADJACENT FLOOR FINISHES. USE MATERIAL CAPABLE OF BEING APPLIED AND FEATHERED OUT TO ADJACENT FLOOR WITHOUT SPALLING.
- PREPARATION: CLEAN FLOORS OF DUST, DIRT, SOLVENTS, OIL, GREASE, PAINT, PLASTER AND OTHER SUBSTANCES DETRIMENTAL TO PROPER PERFORMANCE OF ADHESIVE AND CARPET; ALLOW FLOORS TO BE THOROUGHLY DRY.
- USE LEVELING AND RAMPING MATERIAL TO PATCH CRACKS, SMALL HOLES, LEVELING AND FOR RAMMING TO PROVIDE FINISHED CARPET WITHIN 1/2" OF ADJACENT FLOORING MATERIALS.
- CARPET INSTALLATION: INSTALL CARPET IN ACCORDANCE WITH CARPET MANUFACTURER RECOMMENDATIONS AND INSTALLATION INSTRUCTIONS.
 - PRIME SUBSTRATE IF REQUIRED AND AS RECOMMENDED BY MANUFACTURER; SPREAD ADHESIVE IN QUANTITY RECOMMENDED BY MANUFACTURER TO ENSURE PROPER ADHESION OVER FULL AREA OF INSTALLATION.
 - APPLY ONLY ENOUGH ADHESIVE TO PERMIT PROPER ADHESION OF CARPET BEFORE INITIAL SET.
 - INSTALL CARPET IN ACCORDANCE WITH SEAM DIAGRAM. INSTALL CARPET WITH PILE INCLINATION IN ONE DIRECTION.
 - ALL SEAMS SHALL BE BEADED (BUTTERED) WITH LATEX WITHOUT EXCEPTION.
- INSTALL PROPER TRANSITION CARPET EDGE. RAW CARPET EDGES SHALL BE SECURED AND HELD IN PLACE WITH GRIPPING BAR. EXPOSED CARPET EDGES SHALL BE FINISHED WITH EDGING.
- WHERE CARPET MEETS DISSIMILAR MATERIAL, INSTALL AN APPROVED CARPET EDGE BAR.
- CARPET SHIELDS: G.C. TO PROVIDE CARPET SHIELD TO PROTECT CARPET IMMEDIATELY AFTER CARPET INSTALLATION.

DIVISION 10 - SPECIALTIES

- ACCESS PANEL: FOR GYPSUM BOARD SOFFIT OR WALL: 24" X 24" SURFACE MOUNTED, MODEL #AP24, AS MANUFACTURED BY INTERFORMS INC. (916) 388-9933 OR OTHER WHICH MUST BE APPROVED BY OWNERS CONSTRUCTION MANAGER. SUBSTITUTE WITH "B" LABEL FIRE PANEL, MODEL FW 5050, KEY "B" ONLY IF A RATED DOOR IS REQUIRED PER CODES.
- ACCESS PANELS: FOR HVAC EQUIPMENT AND REFRIGERATION UNITS INDICATED ON THE HVAC AND REFLECTED CEILING PLANS. IN AREAS NOT DEFINED LOCATIONS, THE GENERAL CONTRACTOR IS TO FURNISH AND INSTALL ACCESS PANELS AS NECESSARY TO FURNISH REASONABLE, SAFE ACCESS AND SERVICE ALL SERVICEABLE COMPONENTS OF EACH PIECE OF EQUIPMENT. ASKED ACCESS SHALL BE BY A TECHNICIAN(S) STANDING FIRMLY ON A LADDER. WHERE ACCESS PANELS OR REMOVABLE DIFFUSERS CANNOT BE LOCATED IMMEDIATELY, THE EQUIPMENT IS TO BE REMOVED. THE CONTRACTOR IS TO FURNISH A NON-COMBUSTIBLE CATWALK OR ABOVE CEILING SECURED PLANKING OR METAL DECKING OR SIMILAR NON-COMBUSTIBLE MATERIAL TO PERMIT ACCESS TO THE EQUIPMENT FROM THE NEAREST ACCESS PANEL OR LIFT-OUT DIFFUSER. CATWALKS MUST BE OBSTACLE-FREE TO A HEIGHT OF 3 FOOT 0 INCHES ABOVE THE CATWALK. CATWALKS MUST BE CAPABLE OF SAFELY SUPPORTING A MINIMUM OF TWO (2) TECHNICIANS PLUS EQUIPMENT AND BE CONSTRUCTED OF NON-COMBUSTIBLE MATERIAL.
- THE GENERAL CONTRACTOR IS RESPONSIBLE TO ASSEMBLE ALL MISCELLANEOUS NON-SALES AREA WALL STANDARDS, SHELVES, BRACKETS, ETC.
- LAVATORY FIXTURES & ACCESSORIES: REFER TO MECHANICAL DRAWINGS, CONSTRUCTION PLAN, AND RESPONSIBILITY SCHEDULE.
- RESTORE LANDLORD'S STRUCTURAL STEEL FIREPROOFING TO MAINTAIN INTEGRITY OF SAFE AND FIREPROOF.
- CLEANING: THE G.C. IS RESPONSIBLE FOR 3 PROFESSIONAL CLEANINGS, ONE CLEANING TO BE PRIOR TO THE PUNCH-LIST DATE. THE SECOND IS TO BE AFTER THE STORE IS MERCHANDISED BEFORE THE OPENING DATE. THE THIRD IS JUST PRIOR TO OPENING. STORE IS TO BE TURNED OVER IN A DUST-FREE, DIRT-FREE CONDITION. CLEANING SHALL INCLUDE, BUT NOT BE LIMITED TO THE FOLLOWING:
 - STOREFRONT GLASS (INSIDE AND OUT)
 - MIRRORS
 - STOREFRONT METAL
 - SIGNS
 - LIGHT FIXTURES INCLUDING CANS, TRIM, TRACK AND TRACK HEADS
 - FLOORING (PER MANUFACTURER'S RECOMMENDATIONS)
 - VINYL RESILIENT TILE CLEANED
 - PRESENTATION ITEMS, PROPS, AND TRADE FIXTURES
 - WOOD BASE
 - WALL COVERINGS
 - NON-SALES SHELVING, STORAGE PLATFORMS, ETC.
- AWNINGS - GENERAL: G.C. TO COORDINATE AWNING AND FRAME INSTALLATION WITH OWNER'S PROJECT MANAGER. SUBCONTRACTOR TO PROVIDE BLOCKING AS REQUIRED. COORDINATE WITH OWNER'S VENDOR.

DIVISION 11 - NOT USED

DIVISION 12 - FURNISHINGS

- GENERAL CONTRACTOR IS RESPONSIBLE FOR ASSEMBLY AND PLACEMENT OF OFFICE AND NON-SALES EQUIPMENT AND FURNITURE.
- THE CONTRACTOR IS RESPONSIBLE TO UNGRATE, ASSEMBLE, AND PLACE TRADE FIXTURES AND PRESENTATION ITEMS IN SALES AREA; FIXTURES TO BE LOCATED PER THE DIRECTION OF THE OWNER.
- SUN CONTROL FILM: (USE ONLY WHEN NOTED IN DRAWINGS).
 - SOLAR CONTROL FILM APPLIED TO EXISTING GLASS.
 - PRODUCT DATA: PROVIDE PRODUCT DATA ON PRODUCTS TO BE PROVIDED, SHOWING PHYSICAL PROPERTIES AND INCLUDING INSTALLATION INSTRUCTIONS.
 - TEST DATA: INDEPENDENT TESTING AGENCY REPORTS SHOWING COMPLIANCE WITH PROPERTIES SPECIFIED BY REFERENCE TO A TEST METHOD.
 - PROVIDE FILM MANUFACTURER'S 10-YEAR WARRANTY AGAINST FAILURE OF FILM, INCLUDING CHANGE OF COLOR, PEELING, BUBBLING, RIPPING, CRACKING, DELAMINATION, AND DEMETALIZATION; INCLUDE COST OF MATERIAL AND LABOR FOR REMOVAL AND REINSTALLATION.
 - MANUFACTURER: SOUTHWALL TECHNOLOGIES; REPRESENTED BY V-KOOL, INC.; 17356B NORTHWEST FREEWAY, HOUSTON, TX 77040. ASD. TEL: (800) 786-2468. FAX: (713) 856-8998. EMAIL: %SALES@V-KOOL-USA.COM WWW.V-KOOL-USA.COM
 - SOLAR CONTROL FILM: SOUTHWALL TECHNOLOGIES V-KOOL VK-70 FILM: VIRTUALLY CLEAR SELF-ADHESIVE POLYESTER FILM.
 - SOLAR CONTROL FILM: SOUTHWALL TECHNOLOGIES V-KOOL VK-40 FILM: GRAY TINTED SELF-ADHESIVE POLYESTER FILM.
 - INSTALL IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.
 - INSTALL WITHOUT BUBBLES, RIPPLES, DRIPS, DIRT, CUTS, TEARS, OR GAPS BETWEEN FILM AND FRAME.
 - CLEAN NEWLY INSTALLED FILM AND WINDOW FRAMES.
 - REMOVE CLEANING SOLUTIONS, RUN-OFF CLEANING WATER, AND ADHESIVE MOUNTING SOLUTION FROM ADJACENT SURFACES.
 - WHERE INSTALLED FILM COULD BE DAMAGED BY SUBSEQUENT CONSTRUCTION WORK, PROVIDE TAPE WARNING STRIPS OR BARRICADES TO PREVENT CONTACT.
- INTERIOR WINDOW FILM:
 - APPLY TO STOREFRONT GLASS AS INDICATED IN DRAWINGS.
 - PRODUCT DATA: PROVIDE PRODUCT DATA ON PRODUCTS TO BE PROVIDED, SHOWING PHYSICAL PROPERTIES AND INCLUDING INSTALLATION INSTRUCTIONS.
 - TEST DATA: INDEPENDENT TESTING AGENCY REPORTS SHOWING COMPLIANCE WITH PROPERTIES SPECIFIED BY REFERENCE TO A TEST METHOD.
 - PROVIDE FILM MANUFACTURER'S 10 YEAR WARRANTY AGAINST FAILURE OF FILM, INCLUDING CHANGE OF COLOR, PEELING, BUBBLING, RIPPING, CRACKING, DELAMINATION, AND DEMETALIZATION; INCLUDE COST OF MATERIALS AND LABOR FOR REMOVAL AND REINSTALLATION.
 - MANUFACTURER: 3-M, 3M CORPORATE HEADQUARTERS, 3M CENTER ST. PAUL, MN 55144-1000, 1-888-364-3577
 - INSTALL IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.
 - INSTALL WITHOUT BUBBLES, RIPPLES, DRIPS, DIRT, CUTS, TEARS, OR GAPS BETWEEN FILM AND FRAME.
 - CLEAN NEWLY INSTALLED FILM AND WINDOW FRAMES.
 - REMOVE CLEANING SOLUTIONS, RUN-OFF CLEANING WATER, AND ADHESIVE MOUNTING SOLUTION FROM ADJACENT SURFACES.
 - WHERE INSTALLED FILM COULD BE DAMAGED BY SUBSEQUENT CONSTRUCTION WORK, PROVIDE TAPE WARNING STRIPS OR BARRICADES TO PREVENT CONTACT.

FRCH I
DESIGN WORLDWIDE

311 ELM STREET
SUITE 600
CINCINNATI, OH 45202
513 241 3000
www.frch.com

chico's

11215 METRO PARKWAY
FT. MYERS, FL. 33966

Soma

STORE NO:
5062

PROJECT LOCATION:
MIROMAR OUTLETS
10801 CORKSCREW ROAD
ESTERO, FL 33928
SPACE #: 407

DESIGN TYPE:

REVISIONS:

REQUIRED BY: DATE

* INDICATES NO REVISION TO THIS SHEET

DRAWN BY: BRW
CHECKED BY: DRI/KMM

ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979-285-0712
WHEN THESE PROPS HAVE BEEN REDUCED
BY 50 PERCENT SCALE WILL BE 50 PERCENT
OF WHAT IS NOTED ON PLANS

DRAWING TITLE:
SPECIFICATIONS

DATE ISSUED:
06/06/2017

PROJECT NO:
034138.000

DRAWING NO:

AS.2