

<p>METAL DOOR AND FRAME - SEE 'DOOR AND FRAME SCHEDULE'</p> <p>NON-SALES</p> <p>SALES</p> <p>NOTE: FRAME MUST BE SET TO FIT TIGHT TO TOP FINISHED FLOOR</p> <p>NOTE: G.C. TO PROVIDE B-LABEL DOORS & FRAME AS NEEDED</p> <p>NOTE: HEAD DETAIL SIMILAR</p>	<p>5/8" GYP. BOARD</p> <p>AT FITTING ROOM AREA</p> <p>AT SALES FLOOR</p> <p>BLOCKING AS REQUIRED</p> <p>'J' CHANNEL TRIM, C.R. LAURENCE D645P (TOP) & D636P (BOTTOM) OR EQUAL, SECURE TO WALL WITH #6 GA. DIA., X 5/8" LONG PANCAKE HEAD SCREWS @ 8" O.C.</p> <p>MIRROR MASTIC ON GYP. BD., PRIMED PRIOR TO INSTALLATION OF MIRROR - SEE NOTE BELOW FOR MASTIC & PRIMER SPECS</p> <p>NOT USED</p>	<p>5/8" GYP. BD. ON METAL STUDS - REFER TO FINISH PLAN</p> <p>4" X 1" HARDWOOD PRIMER BASE - SECURE IN PLACE WITH CONSTRUCTION ADHESIVE AND ANGLE FINISH NAIL - G.C. TO FILL NAIL HOLES TO SMOOTH FINISH, SAND, PRIME, AND PAINT PER FINISH PLAN - ALL SEAMS TO BE BACKCUT 45°</p> <p>REFER TO FINISH PLAN</p> <p>(1) 0.157" DIA. POWDER ACTUATED FASTENER (HILTI X-U OR EQUIVALENT) AT 16" O.C. MAX AND 2' FROM EACH END</p> <p>NOT USED</p>	<p>WALL AS SCHEDULED</p> <p>1" X 6" SCRIBABLE POPLAR BASE (SCRIBED TO 6" AT HIGH POINT) - SECURE IN PLACE WITH CONSTRUCTION ADHESIVE AND ANGLE FINISH NAIL - G.C. TO FILL NAIL HOLES TO SMOOTH FINISH, SAND, PRIME, AND PAINT PER FINISH PLAN - ALL SEAMS TO BE BACKCUT 45°</p> <p>3/4"</p> <p>AT HIGH POINT</p> <p>FLOORING - REFER TO FINISH PLAN</p> <p>SCRIBE BOTTOM OF BASE TO MATCH TOP OF FLOOR TILE</p> <p>NOT USED</p>	<p>FRCH</p> <p>DESIGN WORLDWIDE</p> <p>311 ELM STREET SUITE 600 CINCINNATI, OH 45202 513 241 3000 www.frch.com</p>
<p>DOOR JAMB / HEAD DETAIL</p> <p>3" = 1'-0"</p> <p>S</p>	<p>MIRROR TRIM DETAIL</p> <p>N.T.S.</p> <p>M</p>	<p>FITTING ROOM WALL BASE DETAIL</p> <p>3" = 1'-0"</p> <p>H</p>	<p>WALL BASE DETAIL</p> <p>3" = 1'-0"</p> <p>D</p>	<p>chico's</p> <p>11215 METRO PARKWAY FT. MYERS, FL. 33966</p>
<p>16 GA PLATE 3"x6" W/ (4)-#12 SCREWS IN EACH WALL</p> <p>TOP TRACK OF ADJACENT METAL STUD WALLS</p> <p>NEW, INTERSECTING, SAME HEIGHT METAL STUD WALLS</p> <p>NOTE: MAXIMUM ALLOWABLE HORIZONTAL SPAN OF TOP TRACK (I.E. MAXIMUM DISTANCE BETWEEN CROSS WALL) EQUALS 14'-0"</p> <p>NOT USED</p>	<p>HEADER - REFER TO INTERIOR ELEVATIONS FOR HEIGHT</p> <p>DOUBLE 3 5/8" METAL STUDS W/ 2X4 F.R.T. BLOCKING AT JAMBS - TYP.</p> <p>SHIM SPACE</p> <p>PRE-PRIMED WOOD TRIM ASSEMBLY - SUPPLIED BY OWNER AND INSTALLED BY G.C. - G.C. TO PAINT</p> <p>1/2" X 10" SCRIBABLE HARDWOOD BASE - SUPPLIED BY OWNER AND INSTALLED BY G.C.</p> <p>NOT USED</p>	<p>3/4"</p> <p>3 1/2"</p> <p>T-5</p> <p>NOT USED</p>	<p>CONT. 3 5/8" (OR 6") X 20 GA. TRACK WITH (1) #12 SCREW IN EACH FLANGE OF EACH STUD. SPLICE TRACK LENGTHS AT STUD LOCATIONS, TYP.</p> <p>PROVIDE STANDARD BRIDGING AT 4'-0" O.C. MAX UNLESS FULL HGT SHEATHING IS ATTACHED TO BOTH FACES OF WALL (CONNECT BRIDGING TO STUDS - REFER TO H/A11.2)</p> <p>3 5/8" (OR 6") X 20 GA. METAL STUDS AT 16" O.C. INSTALL METAL BRIDGING AT 4'-0" O.C. AS REQ'D BY CODE.</p> <p>0.157" DIA. POWDER ACTUATED FASTENERS (HILTI X-U OR EQUIVALENT) @ 16" O.C. MAX AND 2' FROM EACH END</p> <p>IF POWDER ACTUATED FASTENERS ARE NOT ALLOWED BY LOCAL BUILDING OFFICIAL, THEN REPLACE WITH 1/4" DIA. HILTI Kwik HUS-EZ CONCRETE SCREWS.</p> <p>FLOOR FINISHES. (SEE FINISH PLAN AND SCHEDULE)</p> <p>(E) FLOOR SLAB</p> <p>FINISHED CEILING (WHERE OCCURS)</p> <p>5/8" GYP. BD. BOTH SIDES, OR ONE SIDE ONLY WHERE OCCURS AT PERIMETER DEMISING WALL</p> <p>NOTES: INSTALL GYP. BD. ON ONE SIDE ONLY AT BACK TO BACK CONDITIONS OR AT PERIMETER CONDITIONS.</p> <p>CONT. 3 5/8" (OR 6") X 20 GA. MTL TRACK WITH (1) #8 SCREW AT EACH FLANGE OF EACH STUD</p> <p>REFER TO STUD MATRIX: F/A11.2</p> <p>NOT USED</p>	<p>Soma</p> <p>STORE NO: 5062</p> <p>PROJECT LOCATION: MIROMAR OUTLETS 10801 CORKSCREW ROAD ESTERO, FL 33928 SPACE #: 407</p>
<p>TOP TRACK TO ADJACENT WALL</p> <p>3" = 1'-0"</p> <p>R</p>	<p>HEAD/JAMB DETAIL</p> <p>3" = 1'-0"</p> <p>L</p>	<p>TRIM PROFILES</p> <p>6" = 1'-0"</p> <p>G</p>	<p>NON-RATED PARTITION</p> <p>1" = 1'-0"</p> <p>C</p>	<p>REVISIONS:</p> <p>REQUIRED BY: DATE</p> <p>2 LKM OWNER COMMENTS 07/25/17</p> <p>* INDICATES NO REVISION TO THIS SHEET</p>
<p>NEW, FULL HEIGHT METAL STUD WALL</p> <p>(4)-#12 SCREWS</p> <p>TOP TRACK OF METAL STUD WALL</p> <p>3"x 3"x 16 GA FRAMING CLIP x 3 1/2" LONG</p> <p>TWO ROWS OF (2)-#12 SCREWS</p> <p>INSTALL 6", 18 GA TRACK BLOCKING ACROSS A MINIMUM OF (3) VERTICAL METAL STUDS. CLIP FLANGES AT EACH VERT AND ATTACH W/ (3)-#8 SCREWS AT EACH VERT.</p> <p>NOT USED</p>	<p>SPIDER TRACK SYSTEM</p> <p>CONVENIENCE OUTLET- REFER TO SHEET A3.1 & ELEC. DRAWINGS</p> <p>(E) STOREFRONT TO REMAIN</p> <p>NOT USED</p>	<p>FASTEN DEFLECTION PLATE</p> <p>SAFING MATERIAL</p> <p>VARIES B.O. (E) STRUCTURE</p> <p>(3) LAYERS 5/8" TYPE 'X' GYP. BD. EACH SIDE TIGHT TO DECK ABOVE.</p> <p>3 5/8" (OR 6") TOP & BOTTOM METAL TRACKS ANCHOR TO STRUCTURE ABOVE AT 24" O.C. MAX. AND 2' FROM EACH END. (PROVIDE DEFLECTION PLATE AT TOP AS REQ'D BY CODE)</p> <p>3 5/8" (OR 6") X 20 GA. METAL STUDS AT 16" O.C.</p> <p>0.157" DIA. POWDER ACTUATED FASTENERS (HILTI X-U OR EQUIVALENT) @ 16" O.C. MAX AND 2' FROM EACH END</p> <p>BASE AND FLOOR FINISHES. (SEE FINISH PLAN AND INTERIOR ELEVATIONS.)</p> <p>(E) FLOOR SLAB</p> <p>CONT. 3 5/8" (OR 6") X 20 GA. MTL TRACK WITH (1) #8 SCREW AT EACH FLANGE OF EACH STUD</p> <p>REFER TO STUD MATRIX: F/A11.2</p> <p>NOTE: ASSEMBLY PER UL #441</p> <p>NOT USED</p>	<p>CONTINUOUS FIRE RETARDANT SEALANT AT TOP AND BOTTOM OF PARTITION, BOTH SIDES.</p> <p>VARIES B.O. (E) STRUCTURE</p> <p>J-SHAPE METAL TRIM, BOTH SIDES.</p> <p>3 5/8" (OR 6") X 20 GA. METAL STUDS AT 16" O.C.</p> <p>3 5/8" (OR 6") TOP & BOTTOM METAL TRACKS ANCHOR TO STRUCTURE ABOVE AT 24" O.C. MAX. AND 2' FROM EACH END. (PROVIDE DEFLECTION PLATE AT TOP AS REQ'D BY CODE)</p> <p>IF POWDER ACTUATED FASTENERS ARE NOT ALLOWED BY LOCAL BUILDING OFFICIAL, THEN REPLACE WITH 1/4" DIA. HILTI Kwik HUS-EZ CONCRETE SCREWS.</p> <p>CONT. 3 5/8" (OR 6") X 20 GA. MTL TRACK WITH (1) #8 SCREW AT EACH FLANGE OF EACH STUD</p> <p>REFER TO STUD MATRIX: F/A11.2</p> <p>NOTE: ASSEMBLY PER UL #465</p> <p>NOT USED</p>	<p>ELITE CONSTRUCTION GROUP LAKE JACKSON, TX PHONE: 979-285-0712 NOTE: THESE PRINTS HAVE BEEN REDUCED BY 50 PERCENT SCALE WILL BE 50 PERCENT OF WHAT IS NOTED ON PLANS</p>
<p>TOP TRACK TO ADJACENT WALL</p> <p>3" = 1'-0"</p> <p>P</p>	<p>SPIDER TRACK DETAIL</p> <p>1" = 1'-0"</p> <p>K</p>	<p>FURRING PARTITION DETAIL</p> <p>1" = 1'-0"</p> <p>F</p>	<p>NON-RATED PARTITION (TO STRUCT.)</p> <p>1" = 1'-0"</p> <p>B</p>	<p>DRAWN BY: BRW CHECKED BY:DR/KMM</p>
<p>LINE OF CEILING</p> <p>NOTE: SEE PER/A11.1 FOR CONNECTION OF CONTINUOUS TOP TRACK TO ADJACENT WALL</p> <p>REFER TO PLAN</p> <p>PROVIDE STANDARD BRIDGING - REFER TO H/A11.2</p> <p>CONT. 3 5/8" X 18 GA. DEEP LEG MTL TRACK WITH (1) #8 SCREW AT EACH FLANGE OF EACH STUD</p> <p>IF POWDER ACTUATED FASTENERS ARE NOT ALLOWED BY LOCAL BUILDING OFFICIAL, THEN REPLACE WITH 1/4" DIA. HILTI Kwik HUS-EZ CONCRETE SCREWS.</p> <p>2 1/2" X (OR 3 5/8") 20 GA. MTL STUDS AT 16" O.C.</p> <p>0.157" DIA. POWDER ACTUATED FASTENERS (HILTI X-U OR EQUIVALENT) @ 16" O.C. MAX AND 2' FROM EACH END</p> <p>FLOOR FINISHES. (SEE FINISH PLAN AND SCHEDULE)</p> <p>(E) FLOOR SLAB</p> <p>REFER TO STUD MATRIX: F/A11.2</p> <p>NOT USED</p>	<p>FIN. CEILING</p> <p>T-5 P-3B</p> <p>G.C. PROVIDED HILTI TOGGLE BOLT #00374496 (TYP.)</p> <p>OWNER PROVIDED SURFACE MTD STANDARDS, INSTALL WHERE INDICATED ON PLAN - INSTALL PER MANUFACTURERS INSTRUCTIONS</p> <p>EXISTING PARTITION</p> <p>FURRING PARTITION</p> <p>WALL BASE</p> <p>FLOOR FINISH 0'-0" FIN. FLOOR</p> <p>NOT USED</p>	<p>2 HOUR RATED PARTITION (U411)</p> <p>3" = 1'-0"</p> <p>E</p>	<p>1 HOUR RATED PARTITION (U465)</p> <p>1" = 1'-0"</p> <p>A</p>	<p>DRAWING TITLE: CONSTRUCTION DETAILS</p> <p>DATE ISSUED: 06/06/2017</p> <p>PROJECT NO: 034138.000</p> <p>DRAWING NO: A11.1</p>
<p>NON-RATED PARTIAL HT. PARTITION</p> <p>1" = 1'-0"</p> <p>N</p>	<p>WALL STANDARD SECTION (SALES)</p> <p>1/2" = 1'-0"</p> <p>J</p>	<p>2 HOUR RATED PARTITION (U411)</p> <p>3" = 1'-0"</p> <p>E</p>	<p>1 HOUR RATED PARTITION (U465)</p> <p>1" = 1'-0"</p> <p>A</p>	