





1. The interior will be a Major Remodel.
2. Consider relocating the interior circulation door to the counter end wall or if it is to remain in its present location re work the seating to provide a minimum of 54" in depth on the pull side of the door.
3. Rework the menu board valance for a straight valance parallel with the front counter.
4. Install vertical grab bars in each restroom and self-closing stall doors.
5. Widen the women's accessible stall to 60" minimum finished.
6. Update the restroom finishes to match the Lobby.
7. Provide accessible seating and training in the Crew Room.
8. Ensure that all crew items (shoes, coat racks, etc. are within the accessible reach ranges of 48" aff x 10" deep.
9. Update the Crew Room finishes to match the Lobby.

ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979-285-0712
NOTE: THESE PRINTS HAVE BEEN
REDUCED BY 50 PERCENT. SCALE
WILL BE 50 PERCENT OF WHAT IS
NOTED ON PLANS

11

SHEET NO.	41-0760.00.0		CV COVER	
TITLE	MRP 2.0 STO REMODEL BUILDING CORE 16 EXTERIOR		DESCRIPTION	
DRAWN BY M.P.	NOV 2015	DATE	NOV 2015	DATE
STUD ISSUE DATE	NOV 2015	DATE	NOV 2015	DATE
REVIEWED BY R.K.	NOV 2015	DATE	NOV 2015	DATE
DATE	NOV 2015	DATE	NOV 2015	DATE
SITE ID	SITE ADDRESS		SITE ID	DESCRIPTION
041-0760	21320 HWY 22 Porters Crossroads		041-0760	WILDERVILLE, TN
PREPARED FOR:		© 2015 McDonald's USA, LLC		PREPARED BY:
 McDonald's USA, LLC These drawings and specifications are the confidential and proprietary property of McDonald's USA, LLC and shall not be copied or reproduced without written authorization. The contract documents we prepare are for use with this specific site. In particular, we do not intend to use on a later time. Use of these drawings and specifications on any other project without the services of properly licensed architects and engineers. Reproduction of the contract documents for reuse on another project is not authorized.		 6-28-2017		
		Taylor & Kempkes ARCHITECTS, P.A. 310 CENTRAL AVE. SUITE 202 NASHVILLE, TN 37203 FAX 615-253-1166 PHONE 615-253-5699		
		REV	DATE	DESCRIPTION
				</