



- 1 LEASELINE
2 MALL BULKHEAD ABOVE
3 5'-0" DIAMETER CLEAR TURNING CIRCLE, T-SHAPED TURNING CLEARANCE, OR OTHER MINIMUM REQUIRED FLOOR AREA.
4 FIRE EXTINGUISHER. REFER TO MEP DRAWINGS FOR SPECIFICATIONS.
5 CENTERLINE OF (E) STOREFRONT ENTRY GRILLE
6 LOCATION OF (E) SENSORMATIC SYSTEM. REFER TO ELECTRICAL DRAWINGS.
7 (N) FLOOR OUTLET, REFER TO ELECTRICAL DRAWINGS.
8 (N) FITTING ROOM HOOKS - G.C. TO PROVIDE IN-WALL BLOCKING AS REQUIRED - REFER TO DETAIL K/AII.7
9 (N) ACCESSIBLE BENCH - G.C. TO PROVIDE IN-WALL BLOCKING TO SECURELY MOUNT BENCH TO WALL - REFER TO DETAIL J/AII.7
10 (N) FITTING ROOM PAGING SYSTEM BUTTON FOR (E) PAGING SYSTEM - REFER TO ELECTRICAL DRAWINGS FOR SPECIFICATIONS AND DETAIL N/AII.7 FOR MOUNTING
11 (N) MIRROR. REFER TO DETAIL N/AII.7
12 (N) PAPER PANTY HOLDER. INSTALL AT 48" A.F.F. W/ VENDOR SUPPLIED SCREENS AND GYP. BD. ANCHORS.
13 LOCATION OF (N) MARKETING GRAPHICS - REFER TO INTERIOR ELEVATIONS, WALL AND FINISH PLAN, AND DETAIL H/A07.4.
14 (E) LEDGE ABOVE.
15 (E) TELEPHONE AND ELECTRICAL PANEL - REFER TO ELECTRICAL DRAWINGS.
16 (N) RECEIVING AREA. REFER TO FLOOR AND WALL FINISH PLAN.
17 (N) BRUSHED STAINLESS STEEL SURFACE MOUNTED CORNER GUARDS - REFER TO SPECIFICATIONS SECTION 102613.
18 (N) DRINKING FOUNTAIN - REFER TO PLUMBING DRAWINGS.
19 (E) HARDWARE STORAGE BIN.
20 (E) PLAN TUBE HOLDER
21 (E) SOUND SYSTEM
22 (E) DREAM STEAMER
23 (E) PROCESSING WORK STATION.
24 (N) HOP SINK - REFER TO PLUMBING DRAWINGS.
25 DOOR CHIME FOR NON-SALES DOOR. IF NOT EXISTING, G.C. TO MOUNT ON NON-PUBLIC SIDE ONLY.
26 (R) WATER HEATER ABOVE.
27 (N) ALL SYSTEM - REFER TO DETAIL D/AII.2
28 G.C. TO MAINTAIN MIN. 4" CLEAR AT EACH SIDE OF MOBILE SHELVING UNITS TO ALL OBSTRUCTIONS.
29 (E) ENGINEERED WOOD FLOORING LAYOUT TO START IN CENTER OF ROOM, TRANSITION, OR DISPLAY WINDOW WITH FULL BOARDS, TYP. AS INDICATED BY HATCHED CIRCLE. NO PERIMETER BOARD SHOULD MEASURE LESS THAN HALF THE WIDTH OF ONE BOARD IN ANY DIRECTION. LAYOUT APPLIES TO ALL ROOMS, U.O.N.
30 FLOOR LEVELING REQUIREMENTS, SALES AREA MAX. SLOPE OF 1/10'-0", STOCKROOM (FOR FIXED SHELVING PAD, MAX. SLOPE 0.5% FOR MOBILE SHELVING, MAX. SLOPE 0.01%)
31 ALL CABINET ROUGH OPENINGS & FINISHED CABINET DIMENSIONS ARE CRITICAL DIMENSIONS. IF FIELD DIMENSION VARIES FROM THOSE SHOWN ON PLAN, LSCDC'S DESIGN MANAGER SHOULD BE NOTIFIED IMMEDIATELY.
32 SAW CUTTING MAY BE REQD FOR INSTALLATION OF NEW SENSORMATIC EQUIPMENT. DASHED LINES INDICATE POSITION OF SENSORMATIC PADS / COILS AT ENTRANCE. OWNER'S VENDOR WILL LAYOUT ANTENNA LOCATIONS PRIOR TO SAW CUTTING. REFER TO ELECTRICAL DRAWINGS FOR SPECIFIC INSTALLATION DETAILS AND REQUIREMENTS. TYP. AT ALL ENTRANCES.
33 ALL G.C. SUPPLIED WOOD TRIM & BLOCKING TO BE FREE FROM ANY KNOTS, DEFECTS, ETC., ONLY CLEAR FINISH GRADE BOARDS WILL BE ACCEPTED BY LSCDC PROJECT MANAGER.
34 G.C. TO PREPARE ALL SLABS AS NECESSARY FOR INSTALLATION OF FINISH FLOORING.
35 (E) INDICATES A REFERENCE DIMENSION WHICH IS NOT CRITICAL AND MAY VARY IN THE FIELD. IF DIMENSION VARIES CONSIDERABLY MORE THAN NOTED ON DRAWINGS, NOTIFY THE LSCDC PROJECT MANAGER IMMEDIATELY.
36 (N) STANDARD PARTITION:
(1) LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE ON MTL STUDS @ 16" O.C. STUDS TO EXTEND MINIMUM 6"-12" ABOVE CEILING.
- INSTALL GYP. BD. ON ONE SIDE ONLY AT BACK TO BACK CONDITIONS (REFER TO SPECIFIC DETAILS).
- AT RESTROOM WALLS ADJACENT TO SALES AREA AND FITTING ROOM WALLS ADJACENT TO NON-SALES AREAS, FILL WITH 3 1/2" FRICITION FIT BATT SOUND ATTENUATION INSULATION (STC 42 OR BETTER).
- USE 6" STUDS FOR PLUMBING WALLS AND PILASTER WALLS AS REQD.
(N) RECESSED STANDARD WALL:
(1) LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE ON RECESSED STANDARD STUDS. SPACE STUDS PER DETAIL A/AII.1 - INSTALL GYP. BD. ON ONE SIDE ONLY AT BACK TO BACK CONDITIONS (REFER TO SPECIFIC DETAILS).
(N) ONE HOUR FIRE BARRIER:
METAL STUDS WITH 5/8" TYPE 'X' GYP.BD ON BOTH SIDES. EXTEND GYP BD TIGHT TO DECK ABOVE OR TIGHT TO BOTTOM OF RATED CEILING. SEE FLOOR PLAN FOR SPECIFIC CONDITION (U.L. #U465)
- 37 (E) SHELVING TO REMAIN
38 (N) MOBILE SHELVING UNITS. REFER TO DETAIL J/AII.1
39 (N) WALL MOUNTED SHELVING. REFER TO DETAIL A/AII.1
40 (E) RECESSED WALL STANDARDS TO REMAIN,
41 (N) RECESSED WALL STANDARDS. REFER TO DETAIL A/AII.1. (TYPICAL AT NEW CABINET LOCATIONS.)
42 (N) WALL STANDARD PANELS IN (E/N) CABINET. REFER TO DETAIL J/AII.1 FOR FURTHER INFORMATION.
43 (E) CASHWRAP OR CASHWRAP. G.C. TO REPLACE COUNTERTOP. REFER TO A00.1 FOR FINISH SPECIFICATIONS.
44 (E) FINISH PANELS. REFER TO DETAIL A00.1 FOR FINISH SPECIFICATIONS.
45 (E) DOOR TO REMAIN. PATCH AND REPAIR AS NECESSARY TO RECEIVE NEW FINISHES. REPLACE DAMAGED OR MISSING HARDWARE. REFER TO A/A00.2
46 (N) FITTING ROOM MIRROR. REFER TO DETAIL N/AII.7 FOR FINISH.
47 (N) FITTING ROOM MIRROR. SEE DETAIL B/AII.7. REFER TO A00.X FOR NEW FINISH.
48 (E) STOREFRONT SYSTEM. REFER TO SHEET A08.X.
49 (N) MIRROR. INSTALL IN 1/2" TRIM AT OPENING SIDES AND RECESS. REFER TO A00.X FOR FINISH.
50 (N) CABINET FIN. SEE DETAIL P/AII.1 AND A05.X FOR FINISH.
51 (E) RESTROOM W/ ACCESSIBLE FIXTURES TO REMAIN. G.C. TO CONFORM COMPLIANCE WITH ADA. IF NOT COMPLIANT, G.C. TO NOTIFY LSCDC PM FOR REMEDIAL ACTION PLAN.
52 G.C. TO INSTALL (N) T-3/T-2 TRIM AT CORNER. REFER TO A05.X FOR FINISH.
53 (R) HAND DRYER. RELOCATE AS NECESSARY TO BE CODE COMPLIANT.
- REFER TO SHEET A00.2 FOR DOOR SCHEDULE
- NOTE: HATCHED AREA INDICATES AREA NOT INCLUDED IN SCOPE. G.C. TO VERIFY ALL FIXTURES ARE IN GOOD WORKING CONDITION AND TOUCH UP FINISHES AS NECESSARY.

CONSTRUCTION FLOOR PLAN KEYNOTES

1. ALL DIMENSIONS SHOWN ON CONSTRUCTION PLAN ARE TO FACE OF GYP. BD OR TO FACE OF FINISH U.O.N. SEE CONSTRUCTION DETAILS FOR CLARIFICATION.
2. ALL ANGLED WALLS ARE TO BE 45° U.O.N. ON PLAN OR CONSTRUCTION DETAILS.
3. FLOOR LEVELING REQUIREMENTS, SALES AREA MAX. SLOPE OF 1/10'-0", STOCKROOM (FOR FIXED SHELVING PAD, MAX. SLOPE 0.5% FOR MOBILE SHELVING, MAX. SLOPE 0.01%)
4. ALL CABINET ROUGH OPENINGS & FINISHED CABINET DIMENSIONS ARE CRITICAL DIMENSIONS. IF FIELD DIMENSION VARIES FROM THOSE SHOWN ON PLAN, LSCDC'S DESIGN MANAGER SHOULD BE NOTIFIED IMMEDIATELY.
5. SAW CUTTING MAY BE REQD FOR INSTALLATION OF NEW SENSORMATIC EQUIPMENT. DASHED LINES INDICATE POSITION OF SENSORMATIC PADS / COILS AT ENTRANCE. OWNER'S VENDOR WILL LAYOUT ANTENNA LOCATIONS PRIOR TO SAW CUTTING. REFER TO ELECTRICAL DRAWINGS FOR SPECIFIC INSTALLATION DETAILS AND REQUIREMENTS. TYP. AT ALL ENTRANCES.
6. ALL G.C. SUPPLIED WOOD TRIM & BLOCKING TO BE FREE FROM ANY KNOTS, DEFECTS, ETC., ONLY CLEAR FINISH GRADE BOARDS WILL BE ACCEPTED BY LSCDC PROJECT MANAGER.
7. G.C. TO PREPARE ALL SLABS AS NECESSARY FOR INSTALLATION OF FINISH FLOORING.
8. (E) INDICATES A REFERENCE DIMENSION WHICH IS NOT CRITICAL AND MAY VARY IN THE FIELD. IF DIMENSION VARIES CONSIDERABLY MORE THAN NOTED ON DRAWINGS, NOTIFY THE LSCDC PROJECT MANAGER IMMEDIATELY.
9. ENGINEERED WOOD FLOORING LAYOUT TO START IN CENTER OF ROOM, TRANSITION, OR DISPLAY WINDOW WITH FULL BOARDS, TYP. AS INDICATED BY HATCHED CIRCLE. NO PERIMETER BOARD SHOULD MEASURE LESS THAN HALF THE WIDTH OF ONE BOARD IN ANY DIRECTION. LAYOUT APPLIES TO ALL ROOMS, U.O.N.
10. TILE LAYOUT TO START IN CENTER OF ROOM W/HULL TILE(S), TYP. NO PERIMETER TILE SHOULD MEASURE LESS THAN HALF THE WIDTH OF ONE TILE IN ANY DIRECTION. LAYOUT APPLIES TO ALL ROOMS, U.O.N.
11. HATCHED TILE INDICATES START LAYOUT IN CENTER OF TRANSITION, PORTAL OR DISPLAY W/ FULL TILE(S). NO PERIMETER TILE SHALL MEASURE LESS THAN HALF THE WIDTH OF A TILE IN ANY DIRECTION.
12. AT ALL TRANSITIONS EXCEPT BETWEEN PINK ROOMS, ALIGN THE OUTSIDE EDGE OF THE TILES W/ FACE OF THE BASE, NOT GYP.BD.
13. ALL TILE GROUT JOINTS TO BE 1/8" WIDE U.O.N.

FLOOR PLAN GENERAL NOTES

HATCH	WALL TYPE / DESCRIPTION	DETAIL
	(E) PARTITION AND/OR TENANT SEPARATION (DEMISING) WALLS. REPAIR OR REPLACE 5/8" TYPE 'X' GYP. BD. IF REQUIRED TO MAINTAIN FIRE RATING (U.L. #U465) (N) STANDARD PARTITION: (1) LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE ON MTL STUDS @ 16" O.C. STUDS TO EXTEND MINIMUM 6"-12" ABOVE CEILING. - INSTALL GYP. BD. ON ONE SIDE ONLY AT BACK TO BACK CONDITIONS (REFER TO SPECIFIC DETAILS). - AT RESTROOM WALLS ADJACENT TO SALES AREA AND FITTING ROOM WALLS ADJACENT TO NON-SALES AREAS, FILL WITH 3 1/2" FRICITION FIT BATT SOUND ATTENUATION INSULATION (STC 42 OR BETTER). - USE 6" STUDS FOR PLUMBING WALLS AND PILASTER WALLS AS REQD. (N) RECESSED STANDARD WALL: (1) LAYER 5/8" TYPE 'X' GYP. BD. EACH SIDE ON RECESSED STANDARD STUDS. SPACE STUDS PER DETAIL A/AII.1 - INSTALL GYP. BD. ON ONE SIDE ONLY AT BACK TO BACK CONDITIONS (REFER TO SPECIFIC DETAILS). (N) ONE HOUR FIRE BARRIER: METAL STUDS WITH 5/8" TYPE 'X' GYP.BD ON BOTH SIDES. EXTEND GYP BD TIGHT TO DECK ABOVE OR TIGHT TO BOTTOM OF RATED CEILING. SEE FLOOR PLAN FOR SPECIFIC CONDITION (U.L. #U465)	A AII.1 B AII.1

- PARTITION GENERAL NOTES
- ALL LIGHT GAGE METAL FRAMING TO COMPLY WITH THE SSMA (STEEL STUD MANUFACTURERS ASSOCIATION) TABLES AND GUIDELINES. REFER TO STRUCTURAL DRAWINGS FOR REED STUD SIZES, GAGE AND SPACING. FOR WALLS UNDER DIFFERENT LOADING CONDITIONS OR HEIGHTS, REFER TO THE SSMA TABLES.
 - REFER TO A02.2 FOR ALL BRACING, SLAB ATTACHMENT, AND STRUCTURE / HEAD CONNECTION REQUIREMENTS.
 - FOR WALLS AT BUILD-IN CABINETS THROUGHOUT THE SALES AREA, REFER TO SPECIFIC DETAILS IN THE AII.X - AII.X SHEETS AS INDICATED ON THE FLOOR PLAN FOR FURTHER INFORMATION.
 - GENERAL CONTRACTOR TO CONFORM ACTUAL FIELD CONDITIONS AND COMPLY WITH INDICATED INSTRUCTIONS.
EXISTING DEMISING WALLS TIGHT TO DECK. REPAIR AND/OR REPLACE DRYWALL SURFACES TO LIKE NEW CONDITION.
EXISTING DEMISING WALLS SHORT OF DECK. INSTALL ADDITIONAL METAL FRAMING AND DRYWALL AS REQUIRED TO COMPLETE DEMISING WALL TIGHT TO DECK.
EXISTING DEMISING WALLS SHORT OF DECK. (REQUIRED DUE TO COMMON HVAC PLENUM AND APPROVED BY BUILDING DEPARTMENT)
INSTALL 1" X 2" WIRE MESH SECURITY SCREEN FROM TOP OF PARTITION TIGHT TO DECK ABOVE - G.C. MUST ADVISE LSCDC'S PROJECT MANAGER OF ACTUAL FIELD CONDITIONS IN ORDER TO OBTAIN SPECIFIC INSTALLATION INSTRUCTIONS.

PARTITION SCHEDULE

NO SCALE	A
----------	---

THESE DRAWINGS AND SPECIFICATIONS ARE PREPARED FOR USE ON A SPECIFIC SITE. ANY CHANGES OR MODIFICATIONS TO THESE DRAWINGS AND SPECIFICATIONS, OR ANY OTHER INFORMATION, MUST BE IN WRITING AND APPROVED BY THE DESIGNER. THE DESIGNER SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED BY THE CLIENT OR ANY OTHER PARTY. THE DESIGNER SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED BY THE CLIENT OR ANY OTHER PARTY. THE DESIGNER SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED BY THE CLIENT OR ANY OTHER PARTY.

010500133
VICTORIA'S SECRET
QUAIL SPRINGS MALL
SPACE NO. 119
2501 WEST MEMORIAL RD.
OKLAHOMA CITY, OK 73134
R131SG/142F
2007/684006

PROJECT INFORMATION:
VICTORIA'S SECRET
QUAIL SPRINGS MALL
SPACE NO. 119
2501 WEST MEMORIAL RD.
OKLAHOMA CITY, OK 73134
SCOPE: OPTIMIZATION
DESIGN TYPE: NMA/FORUM AAI
LSCDC PROJECT #: 00060919
A/E PROJECT #:

REVISIONS:
REQUIRED BY: DATE:
ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979.288.0715
NOTE: THESE PRINTS HAVE BEEN
REDUCED BY 50 PERCENT SCALE.
THESE PRINTS WILL BE 50 PERCENT OF WHAT IS
NOTED ON PLANS.

DATE ISSUED: 05.30.2014
DESIGNED BY: KW
DRAWN BY: DB/BV
CHECKED BY:

CONSTRUCTION FLOOR PLAN

DRAWING NUMBER:
A02.2