


"VERIFY ALL FIELD CONDITIONS PRIOR TO BID"

ELECTRICAL LIGHTING CIRCUIT DEMO PLAN

- 1 ELECTRICAL CONTRACTOR SHALL INSTALL OCCUPANCY MOTION SENSOR SWITCH FOR CONTROL OF LIGHTS AS SHOWN. ELECTRICAL CONTRACTOR SHALL SET SWITCH FOR 15 MINUTES. MOUNT AT 44" AFF.
- 2 BREAK-OFF CIRCUIT.
- 3 JUNCTION BOX INSTALLED AT THE CENTERLINE OR MOUNTING PLATE OF WALL SCONCE. SEE ARCHITECTURAL DRAWINGS FOR MOUNTING HEIGHTS.
- 4 LOCATE RF ANTENNA ABOVE CEILING IN ACCESSIBLE LOCATION WITHIN REACH OF ACCESS POINT. MOUNT TO BOTTOM OF STRUCTURE IF POSSIBLE. PROVIDE 1/2" CONDUIT TO RF FOR A GROUP OF (4) RF ANTENNAS.
- 5 EXISTING JUNCTION BOX, TOGGLE DISCONNECT SWITCH IN NON-VISIBLE LOCATION, FINAL CONNECTION FOR 120 VOLT SIGN AND CONDUIT PER DETAIL. SIGN IS FURNISHED WITH INTERNAL GROUND FAULT PROTECTION BY SIGN MANUFACTURER PER N.E.C. ARTICLE 600-236. VERIFY EXACT LOCATION OF JUNCTION BOX WITH SIGN MANUFACTURER. (REUSE EXISTING JUNCTION BOX AND CONDUIT INTO SPACE IF ALREADY INSTALLED. VERIFY IN FIELD EXACT LOCATION ON CANOPY).
- NOTE: THE CIRCUIT FOR SIGNAGE MUST BE A DEDICATED ISOLATED 3-LINE CIRCUIT CONSISTING OF HOT, NEUTRAL, AND GROUND WIRES LEADING DIRECTLY TO THE PANEL.
- 6 REFER TO SHEET E02.01 FOR POWER REQUIREMENTS.
- 7 LIGHT FIXTURES TO BE INSTALLED IN MILLWORK FIXTURE, NOT IN CEILING. VERIFY WITH LS&C.
- 8 LIGHT FIXTURES ARE MOUNTED TO A MOVABLE ACCESS PANEL. INSTALL WITH ENOUGH SLACK TO ALLOW THE PANEL TO FULLY OPEN AND NOT PUT EXCESS TENSION ON THE WIRE. REFER TO ARCHITECTURAL DRAWINGS FOR MORE INFORMATION.

DEMO CKT
EXISTING CKT



1/4" = 1'-0"

A



Limitedbrands
LIMITED STORE PLANNING, INC.
d/b/a STORE DESIGN & CONSTRUCTION
Three Limited Parkway Columbus, Ohio 43230
Telephone: 614.415.7000 Fax: 614.415.7349

THESE DRAWINGS AND SPECIFICATIONS ARE PREPARED FOR USE ON A SPECIFIC SITE. ANY CHANGES TO THE PROJECT SHALL BE MADE AT THE PROJECT SITE OR AT A LATER DATE. THE PROJECT SITE SHALL BE THE RESPONSIBILITY OF THE ARCHITECT. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL, STATE, AND FEDERAL AUTHORITIES. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL, STATE, AND FEDERAL AUTHORITIES. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL, STATE, AND FEDERAL AUTHORITIES.

PROJECT INFORMATION: 010500133

VICTORIA'S SECRET
QUAIL SPRINGS MALL
SPACE NO. 119
2501 WEST MEMORIAL RD.
OKLAHOMA CITY, OK 73134

SCOPE: OPTIMIZATION PACKAGE: NMA/FORUM A41
DESIGN TYPE: GENERATING 2013 (R131Sa)/142Fa
LSD&C PROJECT #: 00060919 A/E PROJECT #: 2007684006

REVISIONS:
REQUIRED BY: DATE:
ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979.285.0715
NOTE: THESE PRINTS HAVE BEEN
REDUCED BY 50 PERCENT SCALE
WILL BE 50 PERCENT OF WHAT IS
NOTED ON PLANS

DATE ISSUED: 05.30.2014
DESIGNED BY: ASB
DRAWN BY: ASB
CHECKED BY: DFG

ELECTRICAL
LIGHTING
DEMO PLAN

DRAWING NUMBER:

E07.1