



"VERIFY ALL FIELD CONDITIONS PRIOR TO BID"

PLUMBING AND FIRE SPRINKLER HEAD PLAN KEYNOTES	NTS	D
	-	04/02/11

- CONNECT (N) 4" SANITARY SEWER BELOW SLAB TO (E) SANITARY SEWER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 4")
- CONNECT (N) 1" COLD WATER TO (E) COLD WATER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 1")
- P.O.C. OF (N) VENT TO (E) VENT LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 1/2")
- 1" CONDENSATE DRAIN ON ROOF TO DISCHARGE TO SPLASH BLOCK. REFER TO DETAIL J ON SHEET P02.04.
- PLUMBING CONTRACTOR TO PROVIDE WATER METER - HIERSEY MODEL NO. 1/2" WVP AT MINIMUM OF 10 GPM. VERIFY LOCATION. MOUNT 40" ABOVE FINISHED FLOOR. MAKE NECESSARY CONNECTIONS AS REQUIRED. METER TO READ IN BALLONS.
- METAL LINER CONDITION - INSTALL CONCEALED SPRINKLER HEAD IN PRE-CUT HOLE IN PANEL. FIRE PROTECTION CONTRACTOR SHALL ENSURE THAT CONCEALED HEAD COVER COMPLETELY COVERS 2-5/8" PRE-DRILLED HOLE.
- ROUTE TO APPROVED GAS METER LOCATION WITH REGULATOR. TOTAL GAS LOAD = 700 CFH AND A TOTAL DEVELOPED LENGTH = 100 FEET. FIELD VERIFY EXACT LOCATION OF METER AND GAS COMPANY REQUIREMENTS.
- EXISTING SPRINKLER HEAD IN THIS AREA TO REMAIN UNCHANGED.

GC TO PROVIDE WRITTEN REPORT TO LSD&C PM ON CONDITION OF EXISTING SEWER TIE-IN REGARDING SLOPE AND FLOW.

- SCOPE WITH CAMERA PRIOR TO CONNECTION
- DO NOT CONNECT WITHOUT LSD&C PM AUTHORIZATION IF SPECS NOT MET

NOTE:  
REFER TO SPECIFICATION BOOKLET FOR ADDITIONAL INFORMATION.

THESE DRAWINGS AND SPECIFICATIONS ARE PREPARED FOR USE ON A SPECIFIC SITE. ANY CHANGES TO THE PROJECT SHALL BE MADE BY THE ARCHITECT. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES. THE ARCHITECT SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.

PROJECT INFORMATION:  
**VICTORIA'S SECRET**  
QUAL SPRINGS MALL  
SPACE NO. 119  
2501 WEST MEMORIAL RD.  
OKLAHOMA CITY, OK 73134

SCOPE: OPTIMIZATION | PACKAGE: NMA/FORUM AA1  
DESIGN TYPE: GENERATING 2013 (R131Sg)/142Fg  
LSD&C PROJECT #: 00060919 A/E PROJECT #: 2007684006

REVISIONS:  
REQUIRED BY: DATE:

ELITE CONSTRUCTION GROUP  
LAKE JACKSON, TX  
PHONE: 979-288-0715  
NOTE: THESE PRINTS HAVE BEEN REDUCED BY 50 PERCENT SCALE. WILL BE 50 PERCENT OF WHAT IS NOTED ON PLANS.

DATE ISSUED: 05.30.2014  
DESIGNED BY: BLS  
DRAWN BY: BLS  
CHECKED BY: JAH


PLUMBING AND  
FIRE SPRINKLER  
HEAD PLAN

DRAWING NUMBER:

P02.2

Limitedbrands  
LIMITED STORE PLANNING, INC.  
d/b/a STORE DESIGN & CONSTRUCTION  
Three Limited Parkway · Columbus, Ohio 43230  
Telephone: 614.415.7000 · Fax: 614.415.7349

M-Engineering  
750 Brookside Blvd.  
Westerville, Ohio 43081  
phone: 614.839.4639  
fax: 614.839.2222  
www.mengineering.us.com



1/4" = 1'-0"

A