

1. LIGHTING SHALL BE CIRCUITED EXACTLY AS SHOWN ON PLANS. CIRCUITING SHALL BE "THRU-WIRING" WHERE AND WHENEVER POSSIBLE. MULTIPLE CONNECTIONS TO A SINGLE LIGHT FIXTURE FOR VOLTAGE DROP CONDITIONS OR AS A RESULT OF A FIELD CONDITION ARE ACCEPTABLE. LIGHT FIXTURES SHALL BE MANUFACTURED TO ACCOMMODATE "THRU-WIRING". ANY RELATED COSTS FOR MULTIPLE CONNECTIONS SHOULD BE INCLUDED IN BID.
2. ELECTRICAL CONTRACTOR'S BID SHALL INCLUDE THE INSTALLATION OF ALL LIGHT FIXTURES AND ASSOCIATED LAMPS FURNISHED BY LSD&C. ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ENSURING THE ADJUSTABILITY OF ALL DIRECTIONAL FIXTURES AFTER INSTALLATION AND AIM THEM PER GC DIRECTION. LIGHT FIXTURE SPECIFICATIONS MAY VARY. IF THIS IS THE CASE, CONTRACTOR IS TO CALL LSD&C PURCHASING AGENT WHO WILL THEN CALL THE DISTRIBUTOR FOR EXACT SPECIFICATION OF LIGHTING FIXTURES. IF THE CEILING SYSTEMS ARE FIRE RATED, ELECTRICAL CONTRACTOR IS TO CLOSELY COORDINATE FIXTURE REQUIREMENTS WITH LSD&C.
3. EMERGENCY AND EXIT LIGHTS SHALL BE INSTALLED AND CIRCUITED PER LOCAL AND LATEST NATIONAL ELECTRICAL CODES. ALL EMERGENCY AND EXIT FIXTURES SHALL BE DUAL VOLTAGE WITH BATTERY BACK UP (120/277 VOLT INPUT). INSTALL A CENTRAL BATTERY SYSTEM WHERE THE USE OF INDIVIDUAL BATTERY UNITS ARE PROHIBITED BY LOCAL CODES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSD&C PROJECT MANAGER FOR DIRECTION.

4. ALL LIGHTING CIRCUITS UP TO 100'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS FROM 100'-1" TO 150'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS 150'-01" UP TO 250'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM. CIRCUITS ABOVE 251'-0" SHALL UTILIZE #6 CONDUCTORS MINIMUM.
5. ELECTRICAL CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS AS REQUIRED FOR A FULLY COMPLETE AND OPERABLE SYSTEM.
6. EXIT/EMERGENCY LIGHTS AT STOREFRONT ARE TO BE CEILING MOUNTED AND CENTERED OVER OPENING. EXIT/EMERGENCY LIGHTS AT DOOR TO NON-SALES SHALL BE CEILING MOUNTED AND CENTERED ABOVE DOOR. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT THE LSD&C PROJECT MANAGER FOR DIRECTION.
7. IT WILL BE THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO UNLOAD INVENTORY AND STORE LIGHTING PACKAGE. THE ELECTRICAL CONTRACTOR WILL ALSO SHIP ANY EXCESS MATERIALS BACK TO THE ELECTRICAL PACKAGE DISTRIBUTOR.

8. ELECTRICAL CONTRACTOR SHALL REFER BACK TO ARCHITECTURAL SHEETS FOR MOUNTING HEIGHTS OF ALL WALL MOUNTED EMERGENCY EGRESS AND EXIT FIXTURES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSD&C PROJECT MANAGER FOR DIRECTION.
9. REFER TO ARCHITECTURAL DRAWINGS FOR COORDINATION AND EXACT LOCATION OF EXIT SIGNS, EMERGENCY LIGHTING FIXTURES, SPEAKERS, DIFFUSERS, AND OTHER ARCHITECTURAL ELEMENTS.
10. THE ELECTRICAL CONTRACTOR MUST INCLUDE IN THE BID TWO (2) HOURS OF START-UP TIME FOR THE LIGHTING CONTROL SYSTEM. THE ELECTRICAL CONTRACTOR WILL BE REQUIRED TO REPAIR OR REPLACE COMPONENTS FOUND TO BE DEFECTIVE. THE ELECTRICAL CONTRACTOR MUST COORDINATE LIGHTING CONTROL START-UP WITH BAS SUPPLIER REPRESENTATIVE. FAILURE TO DO SO MAY REQUIRE THE ELECTRICAL CONTRACTOR TO RETURN TO THE JOB SITE TO PERFORM START-UP AT A FUTURE DATE AT THE ELECTRICAL CONTRACTOR'S OWN EXPENSE.
11. ALL APPURTENANCES PROVIDED WITH LIGHT FIXTURES, OR TRACK, ETC. POLARITY REVERSING ENDS, SHALL BE INSTALLED PER MANUFACTURER'S INSTRUCTIONS.

LIGHTING PLAN CONSTRUCTION NOTES

| SYMBOL | DESCRIPTION | MANUFACTURER & MODEL NUMBER | LAMP | WATTAGE |
|--------|---|---|---|----------|
| AA | 3.5" ROUND ADJUSTABLE REMODEL LED DOWNLIGHT 3000K FLOOD 28 DEGREE MATTE WHITE TRIM | AMERLUX: HDL-HP-R-RDM-20-LED-E-120 / HDL-HP-RA-MWW-FL-3000 | 20 watt Integral 3000K Philips lumiled 85 CRI 50,000 Hrs. | 20 WATTS |
| AC | 8" DIAMETER RECESSED COMPACT FLUORESCENT DOWNLIGHT, CLEAR CONE, MATTE FINISH, ELECTRONIC BALLAST, WITH EM BALLAST TEST SWITCH IN TRIM | LIGHTOLIER: S7142BUEMAE : 8037CCDPE JUND: CBH-126/42T-BN : CB50-CS-BN | 32watt, T4, 4Pin GX24q-3 Base, Triple Compact Fluorescent, 3000K, 82CRI, 16,000 Hrs. | 36 WATTS |
| AG | 2.9" ROUND LED DOWNLIGHT 3000K, FLOOD 28 DEGREE REFLECTOR WITH WHITE FLANGE, MATTE WHITE | AMERLUX: E2-9RD-G2-12-LED-120/ E2-9RD-G2-MWW-FL-3000 | LED, 3000K | 12 WATTS |
| AR | 5" REMODEL LED DOWNLIGHT 900 LUMENS 20 WATTS, 2700K | LIGHTOLIER: 1000LED09R271 / 1013WH | LED | 20 WATTS |
| AS | 5" REMODEL LED DOWNLIGHT 900 LUMENS 20 WATTS, 2700K WITH 90 MINUTE EM | LIGHTOLIER: 1001LED09N271EM / 1013WH | LED | 20 WATTS |
| AP | 4 1/2" X 4 1/2" SQUARE APERTURE COMPACT FLUORESCENT DOWNLIGHT WITH WHITE TRIM | LIGHTOLIER: 4X41S2HU : 4X4PLWH | 32 watt, T4, 4Pin GX24q-3 Base, Triple Compact Fluorescent, 3000K, 82CRI, 16,000 Hrs. | 36 WATTS |
| A8 | 2.9" ROUND ADJUSTABLE LED DOWNLIGHT 300K, FLOOD 28 DEGREE SEMI DIFFUSED REFLECTOR WITH WHITE FLANGE. | AMERLUX: E2-9RA-12-LED-120-FL-3000/ E2-9RA-SOW | LED | 12 WATTS |
| BH | 3.5" ROUND 30 DEG ADJUSTABLE LED DOWNLIGHT 2700K, 28 DEGREE FLOOD OPTIC WITH WHITE TRIM | AMERLUX: HOUSING-HDL-HP-R-20-LED-E-120 TRIM: HDL-HP-RA-MWW-FL-2700 | 1-20 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 20 WATTS |
| BH2 | 3.5" ROUND 30 DEG ADJUSTABLE LED DOWNLIGHT 2700K, 28 DEGREE FLOOD OPTIC WITH MATTE SILVER TRIM | AMERLUX: HOUSING-HDL-HP-R-20-LED-E-120 TRIM: HDL-HP-RA-SLWV-FL-2700 | 1-20 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 20 WATTS |
| C1 | 2 HEAD SEMI-RECESSED LED TRACK FIXTURE, WHITE FINISH, 3000K 28 DEGREE FLOOD BEAM | AMERLUX: HORNET-HP-SR-TRIM-2-18-LED-E-WT -120-FL-FL-WT-3000 | LED | 36 WATTS |
| C3 | 3 HEAD SEMI-RECESSED LED FIXTURE 15 WATT EACH, 3000K W/ (1) FLOOD (2) SPOT BEAM, WHITE FINISH | AMERLUX:HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-SR-TRIM-3-15-LED-E-WT-120-FL-SP-SP-WT-3000 | 3-13 Watt Integral 3000K Philips Lumiled 85 CRI 50,000 HR | 45 WATTS |
| C4 | 3 HEAD SEMI-RECESSED LED FIXTURE WHITE FINISH, 3000K (2) FLOOD & (1) SPOT BEAM WHITE FINISH | AMERLUX:HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-SR-TRIM-3-15-LED-E-WT-120-FL-SP-FL-WT-3000 | 3-15 Watt Integral 3000K Philips Lumiled 85 CRI 50,000 HR | 45 WATTS |
| E5 | 2 HEAD SEMI-RECESSED LED MULTI FIXTURE, SILVER FINISH, 2700K W/ 15 DEGREE OPTIC, 5 DEGREE LUMINIT & HEX (NFL 20 DEGREE) | AMERLUX:HORNET-HP-R/SR-FRAME-2-LED-120/HORNET-HP-SR-TRIM-2-18-LED-E-ST-120-NF-NF-ST-2700-AHST-HEX | 2-18 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 36 WATTS |
| E6 | 3 HEAD SEMI-RECESSED LED MULTI FIXTURE, SILVER FINISH, 2700K W/ 15 DEGREE OPTIC, 5 DEGREE LUMINIT & HEX (NF20 DEGREE) | AMERLUX:HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-SR-TRIM-3-18-LED-E-ST-120-NF-NF-NF-ST-2700-AHST-HEX | 3-18 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 54 WATTS |
| E7 | 4 HEAD SEMI-RECESSED LED MULTI FIXTURE, SILVER FINISH, 2700K W/ 15 DEGREE OPTIC,5 DEGREE LUMINIT & HEX (NF 20 DEGREE) | AMERLUX:HORNET-HP-R/SR-FRAME-4-LED-120/HORNET-HP-SR-TRIM-4-18-LED-E-ST-120-NF-NF-NF-NF-ST-2700-AHST-HEX | 4-18 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 72 WATTS |
| FK | 4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION WIRE GUARD | MERCURY: MM-132-OCT-C-FLB-120V, WG-MM-140, CHAIN/3IT | 32 Watt, T8, Medium BI-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs. | 32 WATTS |

| SYMBOL | DESCRIPTION | MANUFACTURER & MODEL NUMBER | LAMP | WATTAGE |
|--------|--|---|---|----------|
| F9 | 4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, WITH EMERGENCY PACK WITH WIRE GUARD. | MERCURY: MM-132-OCT-C-FLB-120V-EMPK | 32 Watt, T8, Medium BI-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs. | 32 WATTS |
| GH | 2 HEAD RECESSED LED MULTI FIXTURE, BLACK FINISH, 2700K W/ 15 DEGREE OPTIC,10 DEGREE LUMINIT & HEX (MFL 25 DEGREE) | AMERLUX:HORNET-HP-R-TRIM-2-18-LED-E-BT-120-MFL-MFL-BT-2700-AHBT-HEX | 2-18 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 36 WATTS |
| GJ | 3 HEAD RECESSED LED MULTI FIXTURE, WHITE FINISH, 2700K W/ 15 DEGREE OPTIC, 5 DEGREE LUMINIT & HEX (NF 20 DEGREE) | AMERLUX:HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-R-TRIM-3-18-LED-E-WT-120-NF-NF-WT-2700-AHWT-HEX | 3-18 Watt Integral 2700K Philips Lumiled 85 CRI 50,000 HR | 54 WATTS |
| GK | 2 HEAD FULLY RECESSED LED FIXTURE WHITE FINISH, 3000K W/ 28 DEGREE FLOOD BEAM | AMERLUX:HORNET-HP-R-TRIM-2-15-LED-E-WT-120-FL-FL-WT-3000 | 2-15 Watt Integral 3000K Philips Lumiled 85 CRI 50,000 HR | 36 WATTS |
| PD | 18" STEM FLAT MOUNTED INCANDESCENT PENDANT CARRERA FINISH 50 WATT MAX 18" GLOBE HEIGHT | BESA LIGHTING : 11T-412719-A21-SN-FLAT_MOUNT_18" STEM-CARRERA_W/ SATIN_NICKEL | 12 watt Dimmable A19 lamp 2700K E26 base 800 Lumens | 12 WATTS |
| PP | DECORATIVE PENDANT WITH CUSTOM HARD STEM FOR FIXTURE BOTTOM AT 7'-6" | HOLOPHANE: 24R-30DIN-12-L UN-PAINTED-CUSTOM LENGTH (16.5") | 1-8 Watt-A19 Medium Base, Dimmable LED 80 CRI | 8 WATTS |
| PQ | DECORATIVE TABLE LAMP | POTTERY BARN: WARREN PULLEY TASK LAMP | 1-40 Watt Medium Base Antique Thread Carbon Filament, 2,000 HR | 40 WATTS |
| S8 | ULTRA BRITE HIGH OUT PUT LED TAPE LIGHT, COMES IN 12" SECTIONS 4000K (20' MAX PER DRIVER) ADHISIVE TAPE ON BACK SIDE WITH 120V DRIVER | JESCO: DL-FLEX-UPHD-40 JESCO: DL-FLEX-PS JESCO: DL-PS-XX/24V | LED | 3 WATTS |
| S0 | (1) 16" 4000K LINKABLE LED STICK LIGHT 90 DEGREE BEAM ANGLE ALUMINUM FINISH | JESCO: S601-16/40 | LED | 8 WATTS |
| SU | LINEAR LED (LENGTHS PER MILLWORKER) DIMMABLE DRIVER TO BE PROVIDED WITH 6" BLACK DIMMABLE LUTRON PLUG | FELUX: M042, N042 SERIES WITH DIMMABLE DRIVER 0-TRAIL QES-00-7 WATTS & DIMMABLE BLACK PLUG LUTRON: RP-FDU-10-BH | LED 3.8 Watts/H Integral 2700K,80 CRI 40,000HR | 3.8W/FT |
| X6 | THERMOPLASTIC EXIT SIGN, UNIVERSAL MOUNTING CEILING/WALL, LED LAMPS AND INTEGRAL BATTERY BACK UP FOR 90 MINUTES | LIGHTALARM: OLYNOSOP-N HIGH-LITES: BP-LED-5-R | LED | 4 WATTS |
| XC | SINGLE FACE ADJUSTABLE RECESSED OR WALL MOUNT LED EDGE-LIT EXIT SIGN WITH 90 MINUTE BATTERY BACK-UP, WHITE FINISH WITH RED LETTERING ON CLEAR FACEPLATE. | CONTECH: BEVA-SF-R-EM-P EXITRONIX: C800-CR-WB-RC-7C-WH-CSA-120 (CSA APPROVED) STANRO: RMA-SWH-BE-(BURNING MAN) | LED | 3 WATTS |
| XJ | FULLY RECESSED EMERGENCY LIGHT 90 MIN BATTERY BACK UP, WHITE FINISH 2 (35W) MR11 LAMPS | APERION: APR-25-LC-UI | 35 watt, MR11, 2 Pin GU 4 Base, Quartz Halogen, Flood 30', 4,000Hrs. | 50 WATTS |

- NOTES:
- ALL FIXTURES ARE FURNISHED BY LSD&C UNLESS OTHERWISE NOTED.
 - ALL LIGHT FIXTURES AND WIRING METHODS WITHIN PLENUM CEILING SHALL BE "PLENUM APPROVED" AS PER LOCAL ORDINANCES.
 - ALL LIGHT FIXTURES WITH "EM" AFTER FIXTURE DESIGNATION SHALL BE PROVIDED WITH AN EMERGENCY BALLAST, PRODUCING A MINIMUM OF 1000 LUMENS FOR ONE (1) 48" LAMP.
 - ALL FIXTURES SHALL BE 120 VOLT UNLESS OTHERWISE NOTED.

NOT USED

NTS
42N-E041-J00-SCHD
J
11/18/11

LIGHT FIXTURE SCHEDULE - BBW DOMESTIC

NTS
42N-E041-A00-SCHD
A
11/18/11

SHREMSHOCK
Shremshock Engineering, Inc.
6130 S. Sanbury Rd., Westerville, OH 43081
T: 614 545 4550 | F: 614 545 4555 | shremshock.com
TX Registration Number: RF-6996

ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979-284-0712
NOTE: THESE PRINTS HAVE BEEN
REDUCED BY 50 PERCENT. SCALE
WILL BE 50 PERCENT OF WHAT IS
NOTED ON PLANS

Limited brands
LIMITED STORE PLANNING, INC.
d/b/a STORE DESIGN & CONSTRUCTION
Three Limited Parkway • Columbus, Ohio 43230
Telephone: 614.415.7000 • Fax: 614.415.7349

THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSD&C AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF LSD&C. THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSD&C AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF LSD&C. THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSD&C AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF LSD&C. THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSD&C AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF LSD&C.

PROJECT INFORMATION:
24200161
BATH & BODY WORKS
THE GALLERIA II
SPACE INDUSTRIES RD.
5005 WESTHEIMER RD.
HOUSTON, TX 77056
SCOPE:
DESIGN TYPE:
LSD&C PROJECT #:
FULL REMODEL
EASTON-G
00061216
A/E PROJECT #:
PACKAGE:
GENERATION:
A/E PROJECT #:
DATE ISSUED: 3/7/14
DESIGNED BY: JEH
DRAWN BY: JEH
CHECKED BY: RAP
ELECTRICAL
LIGHT FIXTURE
SCHEDULE
DRAWING NUMBER:
E04.01

REVISIONS:
1. BUILDING DEPARTMENT COMMENTS 04/11/14
2. DESIGN CHANGES/ LANDLORD COMMENTS/ 05/26/14
3. MASTERS UPDATES 06/26/14
4. DESIGN CHANGES 06/27/14