



① CONNECT (N) 4" SANITARY SEWER BELOW SLAB TO (E) SANITARY SEWER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 4")

② CONNECT (N) 1 1/2" COLD WATER TO (E) COLD WATER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 1 1/2")

③ P.O.C. OF (N) VENT TO (E) VENT LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 2")

④ 1" CONDENSATE DRAIN AND SECONDARY DRAIN PAN DRAIN FROM AHU-1 TO MOP SINK. REFER TO DETAIL J ON SHEET POS.1.

⑤ PLUMBING CONTRACTOR SHALL PROVIDE AND INSTALL REMOTE CHILLER FOR THE DRINKING FOUNTAIN. MOUNT CHILLER ABOVE CEILING AND MAINTAIN MANUFACTURER'S RECOMMENDED CLEARANCES FOR EQUIPMENT MAINTENANCE. FIELD VERIFY EXACT LOCATION AND REQUIREMENTS. ALSO FIELD VERIFY MOUNTING HEIGHT WITH CONSTRUCTION MANAGER. SEE PLUMBING FIXTURE SCHEDULE ON SHEET POS.1 FOR FURTHER INFORMATION.

⑥ PIPE HOT WATER HEATER DRAIN PAN AND P/T RELIEF VALVE TO INDIRECT DRAIN INTO HUB DRAIN ADJACENT TO MOP SINK. ⚠

GC TO PROVIDE WRITTEN REPORT TO LSD&C PM ON CONDITION OF EXISTING SEWER TIE-IN REGARDING SLOPE AND FLOW.

- SCOPE WITH CAMERA PRIOR TO CONNECTION
- DO NOT CONNECT WITHOUT LSD&C PM AUTHORIZATION IF SPECS NOT MET

PLUMBING AND FIRE SPRINKLER HEAD

NTS

D

11/11/14

**SHREMSHOCK**  
Shremshock Engineering, Inc.  
6130 S. Sunbury Rd. Westerville, OH 43081  
T: 614.545.4550 | F: 614.545.4555 | shremshock.com  
TX Registration Number: #F-5906

**Limitedbrands**  
LIMITED STORE PLANNING, INC.  
d/b/a STORE DESIGN & CONSTRUCTION  
Three Limited Parkway • Columbus, Ohio 43230  
Telephone: 614.415.7000 • Fax: 614.415.7349

**BATH & BODY WORKS**  
THE GALLERIA II  
SPACE NO. 3133  
5006 WESTHEIMER RD.  
HOUSTON, TX 77056

PROJECT INFORMATION:  
24200161  
BATH & BODY WORKS  
THE GALLERIA II  
SPACE NO. 3133  
5006 WESTHEIMER RD.  
HOUSTON, TX 77056

REVISIONS:  
REVISION NO. DATE  
BUILDING DEPARTMENT COMMENTS 04/11/14  
BUILDING DEPARTMENT COMMENTS 05/8/14

ELITE CONSTRUCTION GROUP  
LAKE JACKSON, TX  
PHONE: 979-284-0712  
NOTE: THESE PRINTS HAVE BEEN  
REDUCED BY 50 PERCENT SCALE  
WILL BE 50 PERCENT OF WHAT IS  
NOTED ON PLANS

DATE ISSUED: 3/7/14  
DESIGNED BY: JPM  
DRAWN BY: JPM  
CHECKED BY: WRG

PLUMBING AND FIRE SPRINKLER HEAD PLAN

DRAWING NUMBER:  
P02.01

1/4" = 1'-0"

A