

- |  |   |   |
|--|---|---|
| <p>1. LIGHTING SHALL BE CIRCUITED EXACTLY AS SHOWN ON PLANS. CIRCUITING SHALL BE "THRU-WIRING" WHERE AND WHENEVER POSSIBLE. MULTIPLE CONNECTIONS TO A SINGLE LIGHT FIXTURE FOR VOLTAGE DROP CONDITIONS OR AS A RESULT OF A FIELD CONDITION ARE NOT ACCEPTABLE. LIGHT FIXTURES SHALL BE MANUFACTURED TO ACCOMMODATE "THRU-WIRING". ANY RELATED COSTS FOR MULTIPLE CONNECTIONS SHOULD BE INCLUDED IN BID.</p>  | <p>4. ALL LIGHTING CIRCUITS UP TO 100'-0" IN LENGTH SHALL UTILIZE #12 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS FROM 100'-1" TO 150'-0" IN LENGTH SHALL UTILIZE #10 CONDUCTORS MINIMUM. ALL LIGHTING CIRCUITS 150'-01" UP TO 250'-0" IN LENGTH SHALL UTILIZE #8 CONDUCTORS MINIMUM. CIRCUITS ABOVE 251'-0" SHALL UTILIZE #6 CONDUCTORS MINIMUM.</p> | <p>8. ELECTRICAL CONTRACTOR SHALL REFER BACK TO ARCHITECTURAL SPECS FOR MOUNTING HEIGHTS OF ALL WALL MOUNTED EMERGENCY EGRESS AND EXIT FIXTURES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSODC PROJECT MANAGER FOR DIRECTION.</p>   |
| <p>2. ELECTRICAL CONTRACTOR'S BID SHALL INCLUDE THE INSTALLATION OF ALL LIGHT FIXTURES AND ASSOCIATED LUMENS FURNISHED BY LSODC. ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ENSURING THE ADJUSTABILITY OF ALL DIRECTIONAL FIXTURES AFTER INSTALLATION AND AIM THEM PER GC DIRECTION. LIGHT FIXTURE SPECIFICATIONS MAY VARY. IF THIS IS THE CASE, CONTRACTOR IS TO CALL LSODC PURCHASING AGENT WHENEVER CALL LIGHTING SPECIFICATIONS. ALL LIGHTING SPECIFICATIONS AND THE CEILING SYSTEMS ARE FIRE RATED. ELECTRICAL CONTRACTOR IS TO CLOSELY COORDINATE FIXTURE REQUIREMENTS WITH LSODC.</p> | <p>5. ELECTRICAL CONTRACTOR SHALL MAKE ALL FINAL CONNECTIONS AS REQUIRED FOR A FULLY COMPLETE AND OPERABLE SYSTEM.</p>  | <p>9. REFER TO ARCHITECTURAL DRAWINGS FOR COORDINATION AND EXACT LOCATION OF EXIT SIGNS, EMERGENCY LIGHTING FIXTURES, SPEAKERS, DIFFUSERS, AND OTHER ARCHITECTURAL ELEMENTS.</p>  |
| <p>3. EMERGENCY AND EXIT LIGHTS SHALL BE INSTALLED AND CIRCUITED PER LOCAL AND LATEST NATIONAL ELECTRICAL CODES. ALL EMERGENCY AND EXIT FIXTURES SHALL BE DUAL-VOLTAJ WITH BATTERY BACK UP (120/277 volt INPUT). INSTALL A CENTRAL BATTERY SYSTEM WHERE THE USE OF INDIVIDUAL BATTERY UNITS ARE PROHIBITED BY LOCAL CODES. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT LSODC PROJECT MANAGER FOR DIRECTION.</p>  | <p>6. EXIT/EMERGENCY LIGHTS AT STOREFRONT ARE TO BE CEILING MOUNTED AND CENTERED OVER OPENING. EXIT/EMERGENCY LIGHTS AT DOOR TO NON-SALES SHALL BE CEILING MOUNTED AND CENTERED ABOVE DOOR. IF PLAN LOCATION IS NOT ACCEPTABLE, IMMEDIATELY CONTACT THE ELECTRICAL CONTRACTOR FOR DIRECTION.</p>  | <p>10. THE ELECTRICAL CONTRACTOR MUST INCLUDE IN THE BID TWO (2) HOURS OF START-UP TIME FOR THE LIGHTING CONTROL SYSTEM. THE ELECTRICAL CONTRACTOR WILL BE REQUIRED TO REPAIR OR REPLACE COMPONENTS FOUND TO BE DEFECTIVE. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR NOTIFYING THE PROJECT MANAGER LIGHTING CONTROL SYSTEMS. FAILURE TO DO SO MAY REQUIRE THE ELECTRICAL CONTRACTOR TO RETURN TO THE JOB SITE TO PERFORM START-UP AT A FUTURE DATE AT THE ELECTRICAL CONTRACTOR'S OWN EXPENSE.</p> |
| <p>7. IT WILL BE THE ELECTRICAL CONTRACTOR'S RESPONSIBILITY TO UNLOAD INVENTORY AND STORE LIGHTING PACKAGE. THE ELECTRICAL CONTRACTOR WILL ALSO SHIP ANY EXCESS MATERIALS BACK TO THE ELECTRICAL PACKAGE DISTRIBUTOR.</p>  |   | <p>11. ALL APPURTENANCES PROVIDED WITH LIGHT FIXTURES, OR TRACK, ETC. POLARITY REVERSING ENDS, SHALL BE INSTALLED PER MANUFACTURER'S INSTRUCTIONS.</p>  |

## LIGHTING PLAN CONSTRUCTION NOTES

SYMBOL	DESCRIPTION	MANUFACTURER & MODEL NUMBER	LAMP	WATTAGE	SYMBOL	DESCRIPTION	MANUFACTURER & MODEL NUMBER	LAMP	WATTAGE
AA	3.5" ROUND ADJUSTABLE REMODELER LED DOWNLIGHT 3000K FLOOD 28 DEGREE MATTE WHITE TRIM	AMERLUX: HDL-HP-R-REM-20-LED-E-120 / HDL-HP-RA-MWV-FL-3000	20 watt Integral 3000k Philips lumiled 85 CRI 50,000 Hrs.	20 WATTS	FG	4' SURFACE MOUNTED BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, WITH EMERGENCY PACK, WIRE GUARD.	MERCURY: MM-132-OCT-C-ELB-120V-EMPK	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	32 WATTS
AC	8" DIAMETER RECESSED COMPACT FLUORESCENT DOWNLIGHT, CLEAR CONE, MATTE FINISH, ELECTRONIC BALLAST, WITH EM BALLAST TEST SWITCH IN TRIM	LIGHTOLIER: S7142BLUEM4E : 8037CCDPE JUNO; CBH-126/42I-BN : C850-CS-BN	32watt, T4, 4Pin GX24q-3 Base, Triple Compact Fluorescent, 3000K, 82CRI, 16,000 Hrs.	36 WATTS	FK	4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION WIRE GUARD	MERCURY: MM-132-OCT-C-ELB-120V, WG-MM-140, CHAIN/SET	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	32 WATTS
AG	2.9" ROUND LED DOWNLIGHT 3000K, FLOOD 28 DEGREE REFLECTOR WITH WHITE FLANGE, MATTE WHITE	AMERLUX: E2.9RD-G2-12-LED-120/ E2.9RD-G2-MWV-FL-3000	LED, 3000K	12 WATTS	FM	8" CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, (2) 4' SECTIONS TANDEM WIRED ON ONE BALLAST, QUICK CONNECT PLUGS AND WIRE GUARD.	MERCURY: MM-132-OCT/8TC-C-ELB-120V, (2)WG-MM-140, CHAIN/SET	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	58 WATTS
AP	4 1/2" X 4 1/2" SQUARE APERTURE COMPACT FLUORESCENT DOWNLIGHT WITH WHITE TRIM	LIGHTOLIER: 4X4132HU : 4X4PLWHW	32 watt, T4, 4Pin GX24q-3 Base, Triple Compact Fluorescent, 3000K, 82CRI, 16,000 Hrs.	36 WATTS	FO	16" CHAIN HUNG BARE T8 LAMP FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, (4) 4' SECTIONS TANDEM WIRED ON ONE BALLAST, QUICK CONNECT PLUGS AND WIRE GUARD.	MERCURY: MM-132-OCT/16T-C-ELB-120V, (4)WG-MM-140, CHAIN/SET	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	112 WATTS
AR	5" REMODEL LED DOWNLIGHT 900 LUMENS 20 WATTS, 2700K	LIGHTOLIER: 1000LED09R271 / 1013WH	LED	20 WATTS	FR	4' SURFACE MOUNTED BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION WIRE GUARD	MERCURY: MM-132-OCT-C-ELB-120V, WG-MM-140	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	32 WATTS
AS	5" REMODEL LED DOWNLIGHT 900 LUMENS 20 WATTS, 2700K WITH 90 MINUTE EM	LIGHTOLIER: 1001LED09N271EM / 1013WH	LED	20 WATTS	F9	4' CHAIN HUNG BARE LAMP T8 FLUORESCENT STRIP, ELECTRONIC BALLAST, 1 LAMP IN SECTION, WITH EMERGENCY PACK WITH WIRE GUARD.	MERCURY: MM-132-OCT-C-ELB-120V-EMPK	32 Watt, T8, Medium Bi-Pin Base, Linear Fluorescent, 3000K, 82 CRI, 20,000 Hrs.	32 WATTS
C1	2 HEAD SEMI-RECESSED LED TRACK FIXTURE, WHITE FINISH, 3000K 28 DEGREE FLOOD BEAM	AMERLUX: HINET-HP-SR-TRIM-2-18-LED-E-WT-120-FL-FL-WT-3000	LED	36 WATTS	PC	14" GLASS GLOBE FIXTURE WITH 12"PENDANT MOUNTED STEM, FLAT CANOPY, SATIN NICKEL FINISH , SUZI CARRERA GLASS FINISH 100W MAX	BESA : ITT-489719-A19-SN	12 WATT DIMMABLE A19 LAMP 2700K E26 BASE 800 LUMENS	12 WATTS
E3	3 HEADED SEMI-RECESSED LED TRACK FIXTURE 18 WATT EACH 3000K (1)FLOOD AND (2)SPOT BEAM WHITE FINISH	HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-SR-TRIM-3-18-LED-E-WT-120-FL-SP-SP-WT-3000	LED	54 WATTS	PD	18" STEM FLAT MOUNTED INCANDESCENT PENDANT CARRERA FINISH 50 WATT MAX 18" GLOBE HEIGHT	BESA LIGHTING : ITT-412719-A21-SN-FLAT_MOUNT_18" STEM-CARRERA W/ SATIN NICKEL	12 watt Dimmable A19 lamp 2700K E26 base 800 Lumens	12 WATTS
E4	3 HEADED SEMI-RECESSED LED TRACK FIXTURE 18 WATT EACH 3000K (2)FLOOD & (1)SPOT BEAM WHITE FINISH	AMERLUX: HORNET-HP-R/SR-FRAME-3-LED-120/HORNET-HP-SR-TRIM-3-18-LED-E-WT-120-FL-SP-FL-WT-3000	LED	54 WATTS	S8	ULTRA BRITE HIGH OUT PUT LED TAPE LIGHT, COMES IN 12" SECTIONS 4000K (20" MAX PER DRIVER) ADHISIVE TAPE ON BACK SIDE WITH 120V DRIVER	JESCO: DL-FLEX-UPHO-40 JESCO: DL-FLEX-PC JESCO: DL-PS-XX/24V	LED	3 WATTS
					SD	(1) 16" 4000K LINKABLE LED STICK LIGHT 90 DEGREE BEAM ANGLE ALUMINUM FINISH	JESCO: SE601-16/40	LED	8 WATTS
					X6	THERMOPLASTIC EXIT SIGN, UNIVERSAL MOUNTING CEILING/WALL, LED LAMPS AND INTEGRAL BATTERY BACK UP FOR 90 MINUTLS	LIGHTALARMS: OLXNS00R-N MOD-LITES: RP-PLD-3-R	LED	4 WATTS
					XC	SINGLE FACE ADJUSTABLE RECESSED OR WALL MOUNT LED EDGE-LIT EXIT SIGN, WITH 90 MINUTE BATTERY BACK-UP, WHITE FINISH WITH RED LETTERING ON CLEAR FACEPLATE.	CONTECH: BEXA-SF-R-LW-P	LED	3 WATTS
					NOTES: 1. ALL FIXTURES ARE FURNISHED BY LSO&C UNLESS OTHERWISE NOTED. 2. ALL LIGHT FIXTURES AND WIRING METHODS WITHIN PLENUM CEILING SHALL BE "PLENUM APPROVED" AS PER LOCAL ORDINANCES. 3. ALL LIGHT FIXTURES WITH EM AFTER FIXTURE DESIGNATION SHALL BE PROVIDED WITH AN EMERGENCY BALLAST, PRODUCING A MINIMUM OF 1000 LUMENS FOR ONE (1) 48" LAMP. 4. ALL FIXTURES SHALL BE 120 VOLT UNLESS OTHERWISE NOTED.				

**NOT USED**

NTS

## J LIGHT FIXTURE SCHEDULE - BBW DOMESTIC

NTS

**A**

E04.01

DRAWING NUMBER:

## ELECTRICAL LIGHT FIXTURE SCHEDULE

DATE ISSUED: 3/7/14  
DESIGNED BY: JEH  
DRAWN BY: JEH  
CHECKED BY: RAP

ELITE CONSTRUCTION GROUP  
LAKE JACKSON, TX  
PHONE: 979-285-0712  
NOTE: THESE PRINTS HAVE BEEN  
REDUCED BY 50 PERCENT. SCALE  
WILL BE 50 PERCENT OF WHAT IS  
NOTED ON PLANS

REVISIONS:

**PROJECT INFORMATION:**

## BATH & B

## BATH & BODY WORKS

24200161

35N39 NO NOUVEAU

CONSTRUCTION ("USOC").

THESE DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF LSCC AND SHALL NOT BE DISPLAYED IN ANY MANNER OR USED ON ANY OTHER PROJECT EXCEPT BY WRITTEN AGREEMENT WITH LSCC. NO REPRODUCTION OF THESE DRAWINGS AND SPECIFICATIONS SHALL BE MADE WITHOUT THE WRITTEN AUTHORIZATION OF THE LSCC. ALL ORIGINALS OR REPRODUCTIONS OF THESE DRAWINGS AND SPECIFICATIONS MUST BE RETURNED TO LSCC UPON COMPLETION OF THEIR INTENDED USE, UNLESS OTHERWISE AGREED ON BY THE LSCC.

PKG 1+  
141Sa  
130840

FULL REMODEL  
EASTON-G  
00061216

SCOPE:  
DESIGN TYPE:  
LSD&C PROJECT #:

DATE ISSUED: 3/7/14  
DESIGNED BY: JEH  
DRAWN BY: JEH  
CHECKED BY: RAP

## ELECTRICAL LIGHT FIXTURE SCHEDULE

DRAWING NUMBER:

E04.01

Limited brands

**LIMITED STORE PLANNING, INC.**  
**d/b/a STORE DESIGN & CONSTRUCTION**  
 Three Limited Parkway • Columbus, Ohio 43230  
 Telephone: 614.415.7000 • Fax: 614.415.7349

**SHREMSHOCK**  
Shremshock Engineering, Inc.  
6130 S. Sunbury Rd. Westerville, OH 43081  
t: 614 545 4550 | f: 614 545 4555 | [shremshock.com](http://shremshock.com)  
TX Registration Number: #F-9566

**SHREMSHOCK**  
Shremshock Engineering, Inc.  
6130 S. Sunbury Rd. Westerville, OH 43081  
t: 614 545 4550 | f: 614 545 4555 | [shremshock.com](http://shremshock.com)  
TX Registration Number: #F-9566