



PLUMBING AND FIRE SPRINKLER HEAD
PLAN KEYNOTES

NTS

D

11/11/11

- CONNECT (N) 4" SANITARY SEWER BELOW SLAB TO (E) SANITARY SEWER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 4")
- CONNECT (N) 1" COLD WATER TO (E) COLD WATER LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 1")
- P.O.C. OF (N) VENT TO (E) VENT LINE. (FIELD VERIFY EXACT SIZE AND LOCATION - MIN. 2")
- 1" CONDENSATE DRAIN FROM EQUIPMENT TO DISCHARGE AT LAVATORY REFER TO DETAILS J & K ON SHEET P03.1.
- PLUMBING CONTRACTOR TO PROVIDE WATER METER (INCLUDE TENANT'S NAME AND SPACE #) - "HERSEY MODEL NO. 3/4" MVR" AT MINIMUM OF 14 GPM. VERIFY LOCATION. MOUNT 48" ABOVE FINISHED FLOOR. MAKE NECESSARY CONNECTIONS AS REQUIRED. METER TO READ IN GALLONS.
- ROUTE TO APPROVED GAS METER LOCATION WITH REGULATOR (PROVIDED AT TRUCK COURT). TOTAL GAS LOAD = 250 CFH AND A TOTAL DEVELOPED LENGTH = 300 FEET. FIELD VERIFY EXACT LOCATION OF METER AND GAS COMPANY REQUIREMENTS.

NOTE:
REFER TO SPECIFICATION BOOKLET FOR ADDITIONAL
INFORMATION.

ANY PENETRATION OR MODIFICATION TO STRUCTURAL STEEL OR
CONCRETE MUST BE COORDINATED AND APPROVED BY THE
LANDLORD'S ON-SITE REPRESENTATIVE AND THE LANDLORD'S
STRUCTURAL ENGINEER.

GC TO PROVIDE WRITTEN REPORT TO LSD&C PM ON CONDITION OF
EXISTING SEWER TIE-IN REGARDING SLOPE AND FLOW.
• SCOPE WITH CAMERA PRIOR TO CONNECTION
• DO NOT CONNECT WITHOUT LSD&C PM AUTHORIZATION IF SPECS
NOT MET