



"VERIFY ALL FIELD CONDITIONS PRIOR TO BID"

- TEMPERATURE AND CARBON DIOXIDE SENSORS FURNISHED BY MANUFACTURER, INSTALLED AND WIRED BY MECHANICAL CONTRACTOR 48" A.F.F. IN SALES AREA AND 60"A.F.F. IN NON-SALES AREA. SEE SHEET M04.01 FOR RESPONSIBILITY SCHEDULE.
- DUCT MOUNTED SUPPLY AIR SMOKE DETECTOR FURNISHED BY FIRE ALARM CONTRACTOR AND INSTALLED IN DUCT BY MECHANICAL CONTRACTOR. POWER WIRING SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR. INTERLOCK TO SHUT DOWN UNIT ON SIGNAL FROM FIRE ALARM SYSTEM.
- TENANT CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION OF ALL HVAC EQUIPMENT. COORDINATE WITH LANDLORD ENGINEER PRIOR TO BID AND CONSTRUCTION.
- EXTEND EXHAUST DUCT UP THROUGH ROOF. PROVIDE A ROOF JACK, STORM COLLAR, AND ALL-WEATHER CAP.
- INSTALL BOTTOM GRILLE AT APPROX. 15'-0" AFF TO BOTTOM OF GRILLE. INSTALL ABOVE CEILING OF ADJACENT SPACE.
- 24"x24" ACCESS PANEL BY GC IN THIS LOCATION FOR ACCESS TO EQUIPMENT ABOVE CEILING. REFER TO ARCHITECTURAL PLANS.
- SUPPLY AIR TEMPERATURE SENSOR FURNISHED BY MANUFACTURER, INSTALLED AND WIRED IN DUCT BY MECHANICAL CONTRACTOR. SEE SHEET M04.01 FOR RESPONSIBILITY SCHEDULE.
- INSTALL SIDEWALL DIFFUSER ON BOTTOM OF ROUND DUCT.
- DROP DUCTWORK DOWN INTO SPACE BEHIND VIDEO WALL. BALANCE TO RETURN 400 CFM.
- PROVIDE FRAMING TO DISTRIBUTE ROOFTOP UNIT WEIGHT BETWEEN THREE JOISTS.

NOTE:
NO ATTACHMENT TO METAL ROOF DECK IS ALLOWED.

NOTE:
ANY EXISTING DEMISING WALL OPENINGS ARE TO REMAIN.

NOTE:
SEE ARCHITECTURAL DRAWINGS FOR CEILING HEIGHTS

MECHANICAL PLAN KEYNOTES

NTS

D
11/11/11

LARSON BINKLEY

Larson Binkley, Inc.
310 W 20th Street, Suite 200
Kansas City, Missouri 64108
Texas Certificate of
Authorization Number F-1367

1 816-997-9601
F 816-997-9602
larsonbinkley.com

Limitedbrands

LIMITED STORE PLANNING, INC.
d/b/a STORE DESIGN & CONSTRUCTION
Three Limited Parkway • Columbus, Ohio 43230
Telephone: 614.415.7000 • Fax: 614.415.7349

024200396

BATH & BODY WORKS

MEMORIAL CITY MALL
303 MEMORIAL CITY WAY
SUITE 735
HOUSTON, TX 77024

PROJECT INFORMATION:
SCOPE: RELO DWN / NEW
DESIGN TYPE: EASTON-C
LSRMC PROJECT # 60685 A/E PROJECT # 13643

REVISIONS:

REVISION	REVISION - REV	DATE
1	STOREROOM REVISION - REV 1	6/10/2014
2	REVISION 2 - LL / PERMIT COMMENTS	6/27/2014

ELITE CONSTRUCTION GROUP
LAKE JACKSON, TX
PHONE: 979-285-0712
NOTE: THESE PRINTS HAVE BEEN
REDUCED BY 50 PERCENT. SCALE
WILL BE 50 PERCENT OF WHAT IS
NOTED ON PLANS

DATE ISSUED: 04/11/2014
DESIGNED BY: JOK
DRAWN BY: JOK
CHECKED BY: JMC

MECHANICAL PLAN

DRAWING NUMBER:
M02.01