


"VERIFY ALL FIELD CONDITIONS PRIOR TO BID"



- TEMPERATURE AND CARBON DIOXIDE SENSORS FURNISHED BY MANUFACTURER, INSTALLED AND WIRED BY MECHANICAL CONTRACTOR 48" A.F.F. IN SALES AREA AND 60"A.F.F. IN NON-SALES AREA. SEE SHEET M04.01 FOR RESPONSIBILITY SCHEDULE.
- DUCT MOUNTED SUPPLY AIR SMOKE DETECTOR FURNISHED BY FIRE ALARM CONTRACTOR AND INSTALLED IN DUCT BY MECHANICAL CONTRACTOR. POWER WIRING SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR. INTERLOCK TO SHUT DOWN UNIT ON SIGNAL FROM FIRE ALARM SYSTEM.
- TENANT CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION OF ALL HVAC EQUIPMENT. COORDINATE WITH LANDLORD ENGINEER PRIOR TO BID AND CONSTRUCTION.
- EXTEND EXHAUST DUCT UP THROUGH ROOF. PROVIDE A ROOF JACK, STORM COLLAR, AND ALL-WEATHER CAP.
- INSTALL BOTTOM GRILLE AT APPROX. 15'-0" AFF TO BOTTOM OF GRILLE. INSTALL ABOVE CEILING OF ADJACENT SPACE.
- 24"x24" ACCESS PANEL BY GC IN THIS LOCATION FOR ACCESS TO EQUIPMENT ABOVE CEILING. REFER TO ARCHITECTURAL PLANS.
- SUPPLY AIR TEMPERATURE SENSOR FURNISHED BY MANUFACTURER, INSTALLED AND WIRED IN DUCT BY MECHANICAL CONTRACTOR. SEE SHEET M04.01 FOR RESPONSIBILITY SCHEDULE.
- INSTALL SIDEWALL DIFFUSER ON BOTTOM OF ROUND DUCT.
- DROP DUCTWORK DOWN INTO SPACE BEHIND VIDEO WALL. BALANCE TO RETURN 400 CFM.
- PROVIDE FRAMING TO DISTRIBUTE ROOFTOP UNIT WEIGHT BETWEEN THREE JOISTS.

NOTE:  
NO ATTACHMENT TO METAL ROOF DECK IS ALLOWED.

NOTE:  
ANY EXISTING DEMISING WALL OPENINGS ARE TO REMAIN.

NOTE:  
SEE ARCHITECTURAL DRAWINGS FOR CEILING HEIGHTS

MECHANICAL PLAN KEYNOTES

NTS

D

11/11/11

**LARSON BINKLEY**

Larson Binkley, Inc.  
310 W 20th Street, Suite 200  
Kansas City, Missouri 64108  
Texas Certificate of  
Authorization Number F-1397

1 816-997-9601  
F 816-997-9602  
lorsonbinkley.com

**Limitedbrands**

LIMITED STORE PLANNING, INC.  
d/b/a STORE DESIGN & CONSTRUCTION  
Three Limited Parkway • Columbus, Ohio 43230  
Telephone: 614.415.7000 • Fax: 614.415.7349

**024200396**

**BATH & BODY WORKS**

**MEMORIAL CITY MALL**

303 MEMORIAL CITY WAY  
SUITE 735  
HOUSTON, TX 77024

RELO DWN / NEW PACKAGE:  
EASTON-C GENERATION:  
60685 A/E PROJECT #:

DATE ISSUED: 04/11/2014  
DESIGNED BY: JOK  
DRAWN BY: JOK  
CHECKED BY: JMC

**MECHANICAL PLAN**

DRAWING NUMBER:  
**M02.01**

PROJECT INFORMATION:  
REVISIONS:  
REVISION 1 - STOREFRONT REVISION - REV 1 6/10/2014  
REVISION 2 - LL / PERMIT COMMENTS 6/27/2014

ELITE CONSTRUCTION GROUP  
LAKE JACKSON, TX  
PHONE: 979-285-0712  
NOTE: THESE PRINTS HAVE BEEN  
REDUCED BY 50 PERCENT. SCALE  
WILL BE 50 PERCENT OF WHAT IS  
NOTED ON PLANS